




ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate								
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost			
1	Heavings less than 1"	6 EA	1	Heavings less than 1"	2 EA	\$ 100.00	\$ 200.00	Curb Ramps	2	2	\$ 3000.00		●	Heavings < 1" (Excluded)***	
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00		●	Heavings ≥ 1" (Excluded)***	
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00		●	Uneven Heaving (Excluded)***	
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00		—	Heaving Clusters (Excluded)	
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00		▲	Sidewalk Joint Gap (Excluded)***	
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00		■	Miscellaneous Obstruction	
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 3000.00		■	■	Missing Sidewalk Obstruction	
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■	■	Other Obstruction	
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■	■	Pole Post Hydrant Obstruction	
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■	■	Ponding Obstruction	
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■	■	Sidewalk Joint Obstruction	
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■	■	Sign Obstruction	
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■	■	Storm Grate Obstruction	
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00					■	■	Transit Obstruction	
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■	■	Traffic Obstruction	
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00					■	■	Tree Obstruction	
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■	■	Utility Obstruction	
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					■	■	Vegetation Obstruction - Low	
19	Vegetation Obstruction - Overhead	1 EA	19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00					■	■	Vegetation Obstruction - Overhead	
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					■	■	Sidewalk Collection Path	
21	Residential Entrance	9 EA	21	Residential Entrance (within slope violation)	5 EA	\$ 3000.00	\$ 15000.00					■	■	Adjacent Sidewalk Collection Path	
22	Total Sidewalk Length Assessed	547.012 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					■	■	Buried Sidewalk	
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	71.73 SY	\$ 75.00	\$ 5380.00					■	■	Sidewalk Not Surveyed	
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00					■	■	Missing Sidewalk Gap	
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00					■	■	No Sidewalk on Block	
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00								
			Sidewalk SubTotal:				\$ 20730.00								

Corridor Total:

\$ 23730.00

■

Curb Ramps - Compliant

■

Curb Ramps - Non Compliant

■

Island Curb Cuts - Compliant

■

Island Curb Cuts - Non Compliant

■

Signals - Compliant

■

Signals - Non Compliant

■

Transit Stops - Compliant

■

Transit Stops - Non Compliant

■

Railroad Crossings - Compliant

■

Railroad Crossings - Non Compliant

■

Accessible Parking - Compliant

■

Accessible Parking - Non Compliant

■

Curb Ramps - Adjacent

■

Island Curb Cuts - Adjacent

■

Signals - Adjacent

■

Transit Stops - Adjacent

■

Railroad Crossings - Adjacent

■

Accessible Parking - Adjacent

● Heavings < 1" (Excluded)*** |

● Heavings ≥ 1" (Excluded)*** |

● Uneven Heaving (Excluded)*** |

— Heaving Clusters (Excluded) |

▲ Sidewalk Joint Gap (Excluded)*** |

■ Miscellaneous Obstruction |

■ Missing Sidewalk Obstruction |

■ Other Obstruction |

■ Pole Post Hydrant Obstruction |

■ Ponding Obstruction |

■ Sidewalk Joint Obstruction |

■ Sign Obstruction |

■ Storm Grate Obstruction |

■ Transit Obstruction |

■ Traffic Obstruction |

■ Tree Obstruction |

■ Utility Obstruction |

■ Vegetation Obstruction - Low |

■ Vegetation Obstruction - Overhead |

— Sidewalk Collection Path |

— Adjacent Sidewalk Collection Path |

— Buried Sidewalk |

— Sidewalk Not Surveyed |

— Missing Sidewalk Gap |

— No Sidewalk on Block |

Cross Slope

■

2 - 3%

■

7.01 - 8%

■

3.01 - 4%

■

8.01 - 9%

■

4.01 - 5%

■

9.01 - 10%

■

5.01% - 6%

■

10.01 - 12%

■

6.01 - 7%

■

> 12%

Running Slope

■

5 - 8.33%

■

8.34% - 10%

■

10.01 - 12.5%

■

> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.