




ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	6 EA	1	Heavings less than 1"	3 EA	\$ 100.00	\$ 300.00	Curb Ramps		4	4	\$ 12800.00	●	Heavings < 1" (Excluded)***
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00	—	Heaving Clusters (Excluded)
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 12800.00	■	Missing Sidewalk Obstruction
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00						■	Other Obstruction
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00						■	Pole Post Hydrant Obstruction
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00						■	Ponding Obstruction
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00						■	Sidewalk Joint Obstruction
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00						■	Sign Obstruction
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00						■	Storm Grate Obstruction
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00						■	Transit Obstruction
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00						■	Traffic Obstruction
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00						■	Tree Obstruction
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00						■	Utility Obstruction
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Low
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Overhead
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00						—	Sidewalk Collection Path
21	Residential Entrance	12 EA	21	Residential Entrance (within slope violation)	7 EA	\$ 3000.00	\$ 21000.00						—	Adjacent Sidewalk Collection Path
22	Total Sidewalk Length Assessed	1284.14 LF	22	Running Slope Violations**	16.581 SY	\$ 75.00	\$ 1244.00						—	Buried Sidewalk
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	78.85 SY	\$ 75.00	\$ 5914.00						—	Sidewalk Not Surveyed
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	53.655 SY	\$ 75.00	\$ 4024.00						—	Missing Sidewalk Gap
25	Missing Sidewalk Gaps (Approx.)	291.459 LF	25	Missing Sidewalk Gaps (Approx.)	291.459 LF	\$ 41.67	\$ 12100.00						—	No Sidewalk on Block
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00							
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00							
			Sidewalk SubTotal:				\$ 32481.00							

Corridor Total:

\$ 57381.00

■

Curb Ramps - Compliant

■

Curb Ramps - Non Compliant

■

Island Curb Cuts - Compliant

■

Island Curb Cuts - Non Compliant

■

Signals - Compliant

■

Signals - Non Compliant

■

Transit Stops - Compliant

■

Transit Stops - Non Compliant

■

Railroad Crossings - Compliant

■

Railroad Crossings - Non Compliant

■

Accessible Parking - Compliant

■

Accessible Parking - Non Compliant

■

Curb Ramps - Adjacent

■

Island Curb Cuts - Adjacent

■

Signals - Adjacent

■

Transit Stops - Adjacent

■

Railroad Crossings - Adjacent

■

Accessible Parking - Adjacent

● Heavings < 1" (Excluded)*** |

● Heavings ≥ 1" (Excluded)*** |

● Uneven Heaving (Excluded)*** |

— Heaving Clusters (Excluded) |

▲ Sidewalk Joint Gap (Excluded)*** |

■ Miscellaneous Obstruction |

■ Missing Sidewalk Obstruction |

■ Other Obstruction |

■ Pole Post Hydrant Obstruction |

■ Ponding Obstruction |

■ Sidewalk Joint Obstruction |

■ Sign Obstruction |

■ Storm Grate Obstruction |

■ Transit Obstruction |

■ Traffic Obstruction |

■ Tree Obstruction |

■ Utility Obstruction |

■ Vegetation Obstruction - Low |

■ Vegetation Obstruction - Overhead |

— Sidewalk Collection Path |

— Adjacent Sidewalk Collection Path |

— Buried Sidewalk |

— Sidewalk Not Surveyed |

— Missing Sidewalk Gap |

— No Sidewalk on Block |

Cross Slope

—

2 - 3%

—

7.01 - 8%

—

3.01 - 4%

—

8.01 - 9%

—

4.01 - 5%

—

9.01 - 10%

—

5.01% - 6%

—

10.01 - 12%

—

6.01 - 7%

—

> 12%

Running Slope

—

5 - 8.33%

—

8.34% - 10%

—

10.01 - 12.5%

—

> 12.5%

*Note:

ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note:

Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note:

Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.