




| ADA Survey Summary |                                   |            | ADA Compliance Cost Estimate * |                                               |           |            |             |
|--------------------|-----------------------------------|------------|--------------------------------|-----------------------------------------------|-----------|------------|-------------|
| Item Description   |                                   | Quantity   | Item Description               |                                               | Quantity  | Unit Price | Item Cost   |
| 1                  | Heavings less than 1"             | 1 EA       | 1                              | Heavings less than 1"                         | 0 EA      | \$ 100.00  | \$ 0.00     |
| 2                  | Heavings 1" or greater            | 0 EA       | 2                              | Heavings 1" or greater                        | 0 EA      | \$ 400.00  | \$ 0.00     |
| 3                  | Uneven Heavings                   | 0 EA       | 3                              | Uneven Heavings                               | 0 EA      | \$ 400.00  | \$ 0.00     |
| 4                  | Heaving Clusters                  | 0 SY       | 4                              | Heaving Clusters                              | 0 SY      | \$ 75.00   | \$ 0.00     |
| 5                  | Sidewalk Joint Gaps               | 0 EA       | 5                              | Sidewalk Joint Gaps                           | 0 EA      | \$ 200.00  | \$ 0.00     |
| 6                  | Miscellaneous Obstruction         | 0 EA       | 6                              | Miscellaneous Obstruction                     | 0 EA      | \$ 1500.00 | \$ 0.00     |
| 7                  | Missing Sidewalk Obstruction      | 0 EA       | 7                              | Missing Sidewalk Obstruction                  | 0 EA      | \$ 200.00  | \$ 0.00     |
| 8                  | Other Obstruction                 | 0 EA       | 8                              | Other Obstruction                             | 0 EA      | \$ 500.00  | \$ 0.00     |
| 9                  | Pole Post Hydrant Obstruction     | 0 EA       | 9                              | Pole Post Hydrant Obstruction                 | 0 EA      | \$ 5000.00 | \$ 0.00     |
| 10                 | Ponding Obstruction               | 0 EA       | 10                             | Ponding Obstruction                           | 0 EA      | \$ 400.00  | \$ 0.00     |
| 11                 | Sidewalk Joint Obstruction        | 0 EA       | 11                             | Sidewalk Joint Obstruction                    | 0 EA      | \$ 100.00  | \$ 0.00     |
| 12                 | Sign Obstruction                  | 0 EA       | 12                             | Sign Obstruction                              | 0 EA      | \$ 150.00  | \$ 0.00     |
| 13                 | Storm Grate Obstruction           | 0 EA       | 13                             | Storm Grate Obstruction                       | 0 EA      | \$700.00   | \$ 0.00     |
| 14                 | Transit Obstruction               | 0 EA       | 14                             | Transit Obstruction                           | 0 EA      | \$500.00   | \$ 0.00     |
| 15                 | Traffic Obstruction               | 0 EA       | 15                             | Traffic Obstruction                           | 0 EA      | \$2000.00  | \$ 0.00     |
| 16                 | Tree Obstruction                  | 0 EA       | 16                             | Tree Obstruction                              | 0 EA      | \$500.00   | \$ 0.00     |
| 17                 | Utility Obstruction               | 0 EA       | 17                             | Utility Obstruction                           | 0 EA      | \$1500.00  | \$ 0.00     |
| 18                 | Vegetation Obstruction - Low      | 0 EA       | 18                             | Vegetation Obstruction - Low                  | 0 EA      | \$150.00   | \$ 0.00     |
| 19                 | Vegetation Obstruction - Overhead | 0 EA       | 19                             | Vegetation Obstruction - Overhead             | 0 EA      | \$150.00   | \$ 0.00     |
| 20                 | Commercial Entrance               | 0 EA       | 20                             | Commercial Entrance (within slope violation)  | 0 EA      | \$ 5000.00 | \$ 0.00     |
| 21                 | Residential Entrance              | 4 EA       | 21                             | Residential Entrance (within slope violation) | 4 EA      | \$ 3000.00 | \$ 12000.00 |
| 22                 | Total Sidewalk Length Assessed    | 247.704 LF | 22                             | Running Slope Violations**                    | 6.165 SY  | \$ 75.00   | \$ 462.00   |
| 23                 | Average Sidewalk Width            | 48 IN      | 23                             | Cross Slope Violations                        | 32.273 SY | \$ 75.00   | \$ 2420.00  |
| 24                 | No Sidewalk on Block (Approx.)    | 0 LF       | 24                             | Running and Cross Slope Violations            | 21.257 SY | \$ 75.00   | \$ 1594.00  |
| 25                 | Missing Sidewalk Gaps (Approx.)   | 0 LF       | 25                             | Missing Sidewalk Gaps (Approx.)               | 0 LF      | \$ 41.67   | \$ 0.00     |
| 26                 | Poor Surface Condition (Approx.)  | 0 LF       | 26                             | Poor Surface Condition (Approx.)              | 0 LF      | \$ 41.67   | \$ 0.00     |
| 27                 | Buried Sidewalk (Approx.)         | 0 LF       | 27                             | Buried Sidewalk (Approx.)                     | 0 LF      | \$ 41.67   | \$ 0.00     |
|                    |                                   |            | Sidewalk SubTotal:             |                                               |           |            | \$ 16477.00 |

| Intersection Inventory & Compliance Cost Estimate |             |                     |      |         |
|---------------------------------------------------|-------------|---------------------|------|---------|
| Item Description                                  | Total Count | Non Compliant Count | Cost |         |
| Curb Ramps                                        | 2           | 2                   | \$   | 6400.00 |
| Island Curb Cuts                                  | 0           | 0                   | \$   | 0.00    |
| Signal Push Buttons                               | 0           | 0                   | \$   | 0.00    |
| Transit Stops                                     | 0           | 0                   | \$   | 0.00    |
| Railroad Crossings                                | 0           | 0                   | \$   | 0.00    |
| Accessible Parking Spaces                         | 0           | 0                   | \$   | 0.00    |
| Intersection Sub Total:                           |             |                     | \$   | 6400.00 |

**Corridor Total:** \$ 22877.00

|                                                                                                                          |                                                                                                                     |
|--------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|
|  Curb Ramps - Compliant             |  Curb Ramps - Adjacent         |
|  Curb Ramps - Non Compliant         |                                                                                                                     |
|  Island Curb Cuts - Compliant       |  Island Curb Cuts - Adjacent   |
|  Island Curb Cuts - Non Compliant   |                                                                                                                     |
|  Signals - Compliant                |  Signals - Adjacent            |
|  Signals - Non Compliant            |                                                                                                                     |
|  Transit Stops - Compliant          |  Transit Stops - Adjacent      |
|  Transit Stops - Non Compliant      |                                                                                                                     |
|  Railroad Crossings - Compliant     |  Railroad Crossings - Adjacent |
|  Railroad Crossings - Non Compliant |                                                                                                                     |
|  Accessible Parking - Compliant     |  Accessible Parking - Adjacent |
|  Accessible Parking - Non Compliant |                                                                                                                     |

- Obstructions**

  - Heavings < 1" (Excluded)\*\*\*
  - Heavings ≥ 1" (Excluded)\*\*\*
  - Uneven Heaving (Excluded)\*\*\*
  - Heaving Clusters (Excluded)
  - Sidewalk Joint Gap (Excluded)\*\*\*
  - Miscellaneous Obstruction
  - Missing Sidewalk Obstruction
  - Other Obstruction
  - Pole Post Hydrant Obstruction
  - Ponding Obstruction
  - Sidewalk Joint Obstruction
  - Sign Obstruction
  - Storm Grate Obstruction
  - Transit Obstruction
  - Traffic Obstruction
  - Tree Obstruction
  - Utility Obstruction
  - Vegetation Obstruction - Low
  - Vegetation Obstruction - Overhead

**Slopes**

**Cross Slope**

  - 2 - 3%
  - 3.01 - 4%
  - 4.01 - 5%
  - 5.01% - 6%
  - 6.01 - 7%
  - 7.01 - 8%
  - 8.01 - 9%
  - 9.01 - 10%
  - 10.01 - 12%
  - > 12%

**Running Slope**

  - 5 - 8.33%
  - 8.34% - 10%
  - 10.01 - 12.5%
  - > 12.5%

**Sidewalk Features**

  - Sidewalk Collection Path
  - Adjacent Sidewalk Collection Path
  - Buried Sidewalk
  - Sidewalk Not Surveyed
  - Missing Sidewalk Gap
  - No Sidewalk on Block

\*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.