




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate								
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item	Description	Total Count	Non Compliant Count	Cost			
1	Heavings less than 1"	3 EA	1	Heavings less than 1"	3 EA	\$ 100.00	\$	300.00	Curb Ramps	6	6	\$	9400.00	
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$	0.00	Island Curb Cuts	1	1	\$	3000.00	
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00	Signal Push Buttons	1	1	\$	400.00	
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$	0.00	Transit Stops	0	0	\$	0.00	
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00	Railroad Crossings	0	0	\$	0.00	
6	Miscellaneous Obstruction	2 EA	6	Miscellaneous Obstruction	2 EA	\$ 1500.00	\$	3000.00	Accessible Parking Spaces	0	0	\$	0.00	
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00	Intersection SubTotal:			\$	12800.00	
8	Other Obstruction	1 EA	8	Other Obstruction	1 EA	\$ 500.00	\$	500.00						
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00						
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00						
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00						
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00						
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00						
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00						
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00						
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00						
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$	0.00						
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$	0.00						
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$	0.00						
20	Commercial Entrance	1 EA	20	Commercial Entrance (within slope violation)	1 EA	\$ 5000.00	\$	5000.00						
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$	0.00						
22	Total Sidewalk Length Assessed	932.5 LF	22	Running Slope Violations**	22.313 SY	\$ 75.00	\$	1673.00						
23	Average Sidewalk Width	96.4 IN	23	Cross Slope Violations	229.199 SY	\$ 75.00	\$	17190.00						
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	35.427 SY	\$ 75.00	\$	2657.00						
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00						
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00						
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$	0.00						
			Sidewalk SubTotal:				\$	30320.00						