




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate									
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost			
1	Heavings less than 1"	92 EA	1	Heavings less than 1"	35 EA	\$ 100.00	\$ 3500.00	Curb Ramps	0	0	\$ 0.00	●	Heavings < 1" (Excluded)***	● Heavings < 1"	
2	Heavings 1" or greater	3 EA	2	Heavings 1" or greater	1 EA	\$ 400.00	\$ 400.00	Island Curb Cuts	0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"	
3	Uneven Heavings	3 EA	3	Uneven Heavings	1 EA	\$ 400.00	\$ 400.00	Signal Push Buttons	0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	● Uneven Heaving	
4	Heaving Clusters	11.099 SY	4	Heaving Clusters	2.22 SY	\$ 75.00	\$ 167.00	Transit Stops	2	2	\$ 2850.00	—	Heaving Clusters (Excluded)	— Heaving Clusters	
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap	
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■	Miscellaneous Obstruction	■ Commercial Entrance	
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 2850.00	■	Missing Sidewalk Obstruction	■ Residential Entrance	
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■	Other Obstruction	■ Commercial Entrance (within slope violation)	
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	Corridor Total:		\$ 210595.00		■	Pole Post Hydrant Obstruction	■ Residential Entrance (within slope violation)	
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■	Ponding Obstruction	Cross Slope	
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■ Curb Ramps - Compliant	■	Curb Ramps - Adjacent		■	Sidewalk Joint Obstruction	2 - 3%	7.01 - 8%
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■ Curb Ramps - Non Compliant	■	Curb Ramps - Adjacent		■	Sign Obstruction	3.01 - 4%	8.01 - 9%
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■ Island Curb Cuts - Compliant	■	Island Curb Cuts - Adjacent		■	Storm Grate Obstruction	4.01 - 5%	9.01 - 10%
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00	■ Island Curb Cuts - Non Compliant	■	Island Curb Cuts - Adjacent		■	Transit Obstruction	5.01% - 6%	10.01 - 12%
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■ Signals - Compliant	■	Signals - Adjacent		■	Traffic Obstruction	6.01 - 7%	> 12%
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00	■ Signals - Non Compliant	■	Signals - Adjacent		■	Tree Obstruction	Running Slope	
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■ Transit Stops - Compliant	■	Transit Stops - Adjacent		■	Utility Obstruction	5 - 8.33%	
18	Vegetation Obstruction - Low	17 EA	18	Vegetation Obstruction - Low	17 EA	\$150.00	\$ 2550.00	■ Transit Stops - Non Compliant	■	Transit Stops - Adjacent		■	Vegetation Obstruction - Low	8.34% - 10%	
19	Vegetation Obstruction - Overhead	1 EA	19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00	■ Railroad Crossings - Compliant	■	Railroad Crossings - Adjacent		■	Vegetation Obstruction - Overhead	10.01 - 12.5%	
20	Commercial Entrance	7 EA	20	Commercial Entrance (within slope violation)	6 EA	\$ 5000.00	\$ 30000.00	■ Railroad Crossings - Non Compliant	■	Railroad Crossings - Adjacent		■	Sidewalk Collection Path	> 12.5%	
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00	■ Accessible Parking - Compliant	■	Accessible Parking - Adjacent		■	Adjacent Sidewalk Collection Path		
22	Total Sidewalk Length Assessed	2994.066 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00	■ Accessible Parking - Non Compliant				■	Buried Sidewalk		
23	Average Sidewalk Width	60 IN	23	Cross Slope Violations	834.163 SY	\$ 75.00	\$ 62562.00					■	Sidewalk Not Surveyed		
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	23.423 SY	\$ 75.00	\$ 1757.00					■	Missing Sidewalk Gap		
25	Missing Sidewalk Gaps (Approx.)	2551.691 LF	25	Missing Sidewalk Gaps (Approx.)	2551.691 LF	\$ 41.67	\$ 106260.00					■	No Sidewalk on Block		
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00								
			Sidewalk SubTotal:				\$ 101485.00								
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.															
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.															
***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.															