











ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate									
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	 Heavings < 1" (Excluded)***	 Heavings < 1"				
1 Heavings less than 1"	72 EA	1 Heavings less than 1"	23 EA	\$ 100.00	\$ 2300.00	Curb Ramps	8	8	\$ 25600.00	 Heavings ≥ 1" (Excluded)***	 Heavings ≥ 1"				
2 Heavings 1" or greater	8 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	 Uneven Heaving (Excluded)***	 Uneven Heaving				
3 Uneven Heavings	4 EA	3 Uneven Heavings	2 EA	\$ 400.00	\$ 800.00	Signal Push Buttons	0	0	\$ 0.00	 Heaving Clusters (Excluded)	 Heaving Clusters				
4 Heaving Clusters	18.121 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	 Sidewalk Joint Gap (Excluded)***	 Sidewalk Joint Gap				
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	 Miscellaneous Obstruction	 Commercial Entrance				
6 Miscellaneous Obstruction	1 EA	6 Miscellaneous Obstruction	1 EA	\$ 1500.00	\$ 1500.00	Accessible Parking Spaces	0	0	\$ 0.00	 Missing Sidewalk Obstruction	 Residential Entrance				
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 25600.00		 Other Obstruction	 Commercial Entrance (within slope violation)				
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					 Pole Post Hydrant Obstruction	 Residential Entrance (within slope violation)				
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					 Ponding Obstruction					
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					 Sidewalk Joint Obstruction	Cross Slope				
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					 Sign Obstruction	 2 - 3%	 7.01 - 8%			
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					 Storm Grate Obstruction	 3.01 - 4%	 8.01 - 9%			
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					 Transit Obstruction	 4.01 - 5%	 9.01 - 10%			
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					 Traffic Obstruction	 5.01% - 6%	 10.01 - 12%			
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					 Tree Obstruction	 6.01 - 7%	 > 12%			
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					 Utility Obstruction	Running Slope				
17 Utility Obstruction	5 EA	17 Utility Obstruction	5 EA	\$1500.00	\$ 7500.00					 Vegetation Obstruction - Low	 5 - 8.33%				
18 Vegetation Obstruction - Low	1 EA	18 Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00					 Vegetation Obstruction - Overhead	 8.34% - 10%				
19 Vegetation Obstruction - Overhead	1 EA	19 Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00					 Sidewalk Collection Path	 10.01 - 12.5%				
20 Commercial Entrance	12 EA	20 Commercial Entrance (within slope violation)	12 EA	\$ 5000.00	\$ 60000.00					 Adjacent Sidewalk Collection Path	 > 12.5%				
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00					 Buried Sidewalk					
22 Total Sidewalk Length Assessed	3744.15 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					 Sidewalk Not Surveyed					
23 Average Sidewalk Width	47.412 IN	23 Cross Slope Violations	726.192 SY	\$ 75.00	\$ 54464.00					 Missing Sidewalk Gap					
24 No Sidewalk on Block (Approx.)	3617.724 LF	24 Running and Cross Slope Violations	37.245 SY	\$ 75.00	\$ 2793.00					 No Sidewalk on Block					
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00										
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00										
27 Buried Sidewalk (Approx.)	83.388 LF	27 Buried Sidewalk (Approx.)	83.388 LF	\$ 41.67	\$ 3520.00										
		Sidewalk SubTotal:			\$ 129658.00	Corridor Total:			\$ 155258.00						
 Curb Ramps - Compliant  Curb Ramps - Non Compliant  Island Curb Cuts - Compliant  Island Curb Cuts - Non Compliant  Signals - Compliant  Signals - Non Compliant  Transit Stops - Compliant  Transit Stops - Non Compliant  Railroad Crossings - Compliant  Railroad Crossings - Non Compliant  Accessible Parking - Compliant  Accessible Parking - Non Compliant  Curb Ramps - Adjacent  Island Curb Cuts - Adjacent  Signals - Adjacent  Transit Stops - Adjacent  Railroad Crossings - Adjacent  Accessible Parking - Adjacent													 Heavings < 1" (Excluded)***  Heavings ≥ 1" (Excluded)***  Uneven Heaving (Excluded)***  Heaving Clusters (Excluded)  Sidewalk Joint Gap (Excluded)***  Miscellaneous Obstruction  Missing Sidewalk Obstruction  Other Obstruction  Pole Post Hydrant Obstruction  Ponding Obstruction  Sidewalk Joint Obstruction  Sign Obstruction  Storm Grate Obstruction  Transit Obstruction  Traffic Obstruction  Tree Obstruction  Utility Obstruction  Vegetation Obstruction - Low  Vegetation Obstruction - Overhead  Sidewalk Collection Path  Adjacent Sidewalk Collection Path  Buried Sidewalk  Sidewalk Not Surveyed  Missing Sidewalk Gap  No Sidewalk on Block ***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate. ***Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way. ***Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.		