




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate				Legend			
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	3 EA	1	Heavings less than 1"	2 EA	\$ 100.00	\$	200.00	Curb Ramps	4	4	\$	9850.00
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$	0.00	Island Curb Cuts	0	0	\$	0.00
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00	Signal Push Buttons	0	0	\$	0.00
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$	0.00	Transit Stops	0	0	\$	0.00
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00	Railroad Crossings	0	0	\$	0.00
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00	Accessible Parking Spaces	0	0	\$	0.00
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00	Intersection SubTotal:			\$	9850.00
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$	0.00	Corridor Total: \$ 29017.00				
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00	Curb Ramps - Compliant	Curb Ramps - Adjacent			
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00	Curb Ramps - Non Compliant	Island Curb Cuts - Adjacent			
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00	Island Curb Cuts - Compliant	Island Curb Cuts - Adjacent			
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00	Island Curb Cuts - Non Compliant	Signals - Adjacent			
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00	Signals - Compliant	Signals - Adjacent			
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00	Signals - Non Compliant	Transit Stops - Adjacent			
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00	Transit Stops - Compliant	Transit Stops - Adjacent			
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00	Transit Stops - Non Compliant	Railroad Crossings - Adjacent			
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$	0.00	Railroad Crossings - Compliant	Accessible Parking - Adjacent			
18	Vegetation Obstruction - Low	1 EA	18	Vegetation Obstruction - Low	1 EA	\$150.00	\$	150.00	Railroad Crossings - Non Compliant				
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$	0.00	Accessible Parking - Compliant				
20	Commercial Entrance	2 EA	20	Commercial Entrance (within slope violation)	1 EA	\$ 5000.00	\$	5000.00	Accessible Parking - Non Compliant				
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$	0.00					
22	Total Sidewalk Length Assessed	992.954 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$	0.00					
23	Average Sidewalk Width	93.6 IN	23	Cross Slope Violations	184.228 SY	\$ 75.00	\$	13817.00					
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	0 SY	\$ 75.00	\$	0.00					
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00					
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00					
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$	0.00					
				Sidewalk SubTotal:			\$	19167.00					