



ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate				Legend			
Item	Description	Quantity		Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	0 EA		1	Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps		1	1	\$ 3200.00	●	Heavings < 1" (Excluded)***
2	Heavings 1" or greater	0 EA		2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***
3	Uneven Heavings	0 EA		3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***
4	Heaving Clusters	0 SY		4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00	▬	Heaving Clusters (Excluded)
5	Sidewalk Joint Gaps	0 EA		5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***
6	Miscellaneous Obstruction	0 EA		6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction
7	Missing Sidewalk Obstruction	0 EA		7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 3200.00	■	Missing Sidewalk Obstruction
8	Other Obstruction	0 EA		8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 7416.00	■	Other Obstruction
9	Pole Post Hydrant Obstruction	0 EA		9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	●	Curb Ramps - Compliant	■	Curb Ramps - Adjacent		■	Pole Post Hydrant Obstruction
10	Ponding Obstruction	0 EA		10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00							
11	Sidewalk Joint Obstruction	0 EA		11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	●	Curb Ramps - Non Compliant	■	Island Curb Cuts - Adjacent		■	Sidewalk Joint Obstruction
12	Sign Obstruction	0 EA		12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	●	Island Curb Cuts - Compliant	■	Island Curb Cuts - Non Compliant		■	Sign Obstruction
13	Storm Grate Obstruction	0 EA		13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	●	Island Curb Cuts - Non Compliant	■	Signals - Adjacent		■	Storm Grate Obstruction
14	Transit Obstruction	0 EA		14	Transit Obstruction	0 EA	\$500.00	\$ 0.00	●	Signals - Compliant	■	Signals - Non Compliant		■	Transit Obstruction
15	Traffic Obstruction	0 EA		15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	●	Signals - Non Compliant	■	Transit Stops - Adjacent		■	Traffic Obstruction
16	Tree Obstruction	0 EA		16	Tree Obstruction	0 EA	\$500.00	\$ 0.00	■	Transit Stops - Compliant	■	Transit Stops - Non Compliant		■	Tree Obstruction
17	Utility Obstruction	0 EA		17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■	Transit Stops - Non Compliant	■	Railroad Crossings - Adjacent		■	Utility Obstruction
18	Vegetation Obstruction - Low	0 EA		18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	■	Railroad Crossings - Compliant	■	Railroad Crossings - Non Compliant		■	Vegetation Obstruction - Low
19	Vegetation Obstruction - Overhead	0 EA		19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	■	Railroad Crossings - Non Compliant	■	Accessible Parking - Adjacent		■	Vegetation Obstruction - Overhead
20	Commercial Entrance	0 EA		20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■	Accessible Parking - Compliant	■	Accessible Parking - Non Compliant		■	Sidewalk Collection Path
21	Residential Entrance	0 EA		21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00	■	Accessible Parking - Non Compliant				■	Adjacent Sidewalk Collection Path
22	Total Sidewalk Length Assessed	197.827 LF		22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00						■	Buried Sidewalk
23	Average Sidewalk Width	48 IN		23	Cross Slope Violations	56.208 SY	\$ 75.00	\$ 4216.00						■	Sidewalk Not Surveyed
24	No Sidewalk on Block (Approx.)	271.104 LF		24	Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00						■	Missing Sidewalk Gap
25	Missing Sidewalk Gaps (Approx.)	0 LF		25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00						■	No Sidewalk on Block
26	Poor Surface Condition (Approx.)	0 LF		26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00							
27	Buried Sidewalk (Approx.)	60.791 LF		27	Buried Sidewalk (Approx.)	60.791 LF	\$ 41.67	\$ 2640.00							
					Sidewalk SubTotal:			\$ 4216.00							