




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost				
1 Heavings less than 1"	0 EA	1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	3	3	\$ 6550.00	● Heavings < 1" (Excluded)***	● Heavings < 1"		
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"		
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	● Uneven Heaving (Excluded)***	● Uneven Heaving		
4 Heaving Clusters	0 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	— Heaving Clusters (Excluded)	— Heaving Clusters		
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap		
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction	◆ Commercial Entrance		
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 6550.00	■ Missing Sidewalk Obstruction	◆ Residential Entrance		
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Other Obstruction	⊕ Commercial Entrance (within slope violation)		
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■ Pole Post Hydrant Obstruction	⊕ Residential Entrance (within slope violation)		
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■ Ponding Obstruction			
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■ Sidewalk Joint Obstruction	Cross Slope		
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■ Sign Obstruction	— 2 - 3% — 7.01 - 8%		
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$ 700.00	\$ 0.00					■ Storm Grate Obstruction	— 3.01 - 4% — 8.01 - 9%		
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Transit Obstruction	— 4.01 - 5% — 9.01 - 10%		
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$ 2000.00	\$ 0.00					■ Traffic Obstruction	— 5.01% - 6% — 10.01 - 12%		
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Tree Obstruction	— 6.01 - 7% — > 12%		
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$ 1500.00	\$ 0.00					■ Utility Obstruction	Running Slope		
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$ 150.00	\$ 0.00					■ Vegetation Obstruction - Low	— 5 - 8.33% —		
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$ 150.00	\$ 0.00					■ Vegetation Obstruction - Overhead	— 8.34% - 10% —		
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					— Sidewalk Collection Path	— 10.01 - 12.5% —		
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00					— Adjacent Sidewalk Collection Path	— > 12.5% —		
22 Total Sidewalk Length Assessed	92.175 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					— Buried Sidewalk			
23 Average Sidewalk Width	48 IN	23 Cross Slope Violations	1.998 SY	\$ 75.00	\$ 150.00					— Sidewalk Not Surveyed			
24 No Sidewalk on Block (Approx.)	160.101 LF	24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00					— Missing Sidewalk Gap			
25 Missing Sidewalk Gaps (Approx.)	96.454 LF	25 Missing Sidewalk Gaps (Approx.)	96.454 LF	\$ 41.67	\$ 3960.00					— No Sidewalk on Block			
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00								
		Sidewalk SubTotal:			\$ 150.00								
						Corridor Total:			\$ 10660.00				
						🚶 Curb Ramps - Compliant		🚶 Curb Ramps - Adjacent					
						🚶 Curb Ramps - Non Compliant		🚶 Curb Ramps - Adjacent					
						🌳 Island Curb Cuts - Compliant		🌳 Island Curb Cuts - Adjacent					
						🚶 Island Curb Cuts - Non Compliant		🚶 Island Curb Cuts - Adjacent					
						🚶 Signals - Compliant		🚶 Signals - Adjacent					
						🚶 Signals - Non Compliant		🚶 Signals - Adjacent					
						🚶 Transit Stops - Compliant		🚶 Transit Stops - Adjacent					
						🚶 Transit Stops - Non Compliant		🚶 Transit Stops - Adjacent					
						🚶 Railroad Crossings - Compliant		🚶 Railroad Crossings - Adjacent					
						🚶 Railroad Crossings - Non Compliant		🚶 Railroad Crossings - Adjacent					
						🚶 Accessible Parking - Compliant		🚶 Accessible Parking - Adjacent					
						🚶 Accessible Parking - Non Compliant		🚶 Accessible Parking - Adjacent					
										*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.			
										**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.			