




ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate														
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost													
1 Heavings less than 1"	8 EA	1 Heavings less than 1"	2 EA	\$ 100.00	\$ 200.00	Curb Ramps	0	0	\$ 0.00	● Heavings < 1" (Excluded)*** ● Heavings ≥ 1" (Excluded)*** ● Uneven Heaving (Excluded)***	● Heavings < 1" ● Heavings ≥ 1" ● Uneven Heaving	▲ Sidewalk Joint Gap (Excluded)*** ■ Miscellaneous Obstruction ■ Missing Sidewalk Obstruction ■ Other Obstruction ■ Pole Post Hydrant Obstruction ■ Ponding Obstruction ■ Sidewalk Joint Obstruction ■ Sign Obstruction ■ Storm Grate Obstruction ■ Transit Obstruction ■ Traffic Obstruction ■ Tree Obstruction ■ Utility Obstruction ■ Vegetation Obstruction - Low ■ Vegetation Obstruction - Overhead ■ Sidewalk Collection Path ■ Adjacent Sidewalk Collection Path ■ Buried Sidewalk ■ Sidewalk Not Surveyed ■ Missing Sidewalk Gap ■ No Sidewalk on Block	▲ Sidewalk Joint Gap ◆ Commercial Entrance ◆ Residential Entrance + Commercial Entrance (within slope violation) + Residential Entrance (within slope violation)									
2 Heavings 1" or greater	1 EA	2 Heavings 1" or greater	1 EA	\$ 400.00	\$ 400.00	Island Curb Cuts	0	0	\$ 0.00													
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00													
4 Heaving Clusters	0 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00							Cross Slope 2 - 3% 3.01 - 4% 4.01 - 5% 5.01% - 6% 6.01 - 7% 7.01 - 8% 8.01 - 9% 9.01 - 10% 10.01 - 12% > 12%	Running Slope 5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5%					
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00													
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00													
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 0.00													
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 19876.00												
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■ Curb Ramps - Compliant		■ Curb Ramps - Adjacent														
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■ Curb Ramps - Non Compliant		■ Island Curb Cuts - Adjacent														
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	▲ Island Curb Cuts - Compliant		▲ Island Curb Cuts - Non Compliant														
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	▲ Island Curb Cuts - Non Compliant		⌘ Signals - Adjacent														
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	⌘ Signals - Compliant		⌘ Transit Stops - Adjacent														
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	⌘ Signals - Non Compliant		⌘ Railroad Crossings - Adjacent														
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■ Transit Stops - Compliant		⌘ Accessible Parking - Adjacent														
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	■ Transit Stops - Non Compliant																
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	⌘ Railroad Crossings - Compliant																
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	⌘ Railroad Crossings - Non Compliant																
19 Vegetation Obstruction - Overhead	1 EA	19 Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00	⌘ Accessible Parking - Compliant																
20 Commercial Entrance	2 EA	20 Commercial Entrance (within slope violation)	2 EA	\$ 5000.00	\$ 10000.00	⌘ Accessible Parking - Non Compliant																
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00																	
22 Total Sidewalk Length Assessed	423.526 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00																	
23 Average Sidewalk Width	60 IN	23 Cross Slope Violations	121.676 SY	\$ 75.00	\$ 9126.00																	
24 No Sidewalk on Block (Approx.)	0 LF	24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00																	
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00																	
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00																	
27 Buried Sidewalk (Approx.)	482.205 LF	27 Buried Sidewalk (Approx.)	482.205 LF	\$ 41.67	\$ 20020.00																	
		Sidewalk SubTotal:			\$ 19876.00																	

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.