




ADA Survey Summary			ADA Compliance Cost Estimate *			
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost
1 Heavings less than 1"	2 EA		1 Heavings less than 1"	2 EA	\$ 100.00	\$ 200.00
2 Heavings 1" or greater	1 EA		2 Heavings 1" or greater	1 EA	\$ 400.00	\$ 400.00
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00
21 Residential Entrance	3 EA		21 Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$ 6000.00
22 Total Sidewalk Length Assessed	440.38 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00
23 Average Sidewalk Width	72 IN		23 Cross Slope Violations	15.313 SY	\$ 75.00	\$ 1148.00
24 No Sidewalk on Block (Approx.)	402.854 LF		24 Running and Cross Slope Violations	36.556 SY	\$ 75.00	\$ 2742.00
25 Missing Sidewalk Gaps (Approx.)	0 LF		25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00
27 Buried Sidewalk (Approx.)	0 LF		27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00
			Sidewalk SubTotal:			\$ 10490.00

Intersection Inventory & Compliance Cost Estimate			
Item Description	Total Count	Non Compliant Count	Cost
Curb Ramps	0	0	\$ 0.00
Island Curb Cuts	0	0	\$ 0.00
Signal Push Buttons	0	0	\$ 0.00
Transit Stops	0	0	\$ 0.00
Railroad Crossings	0	0	\$ 0.00
Accessible Parking Spaces	0	0	\$ 0.00
Intersection SubTotal:			\$ 0.00

Corridor Total:

\$ 10490.00

Curb Ramps - Compliant

Curb Ramps - Non Compliant

Island Curb Cuts - Compliant

Island Curb Cuts - Non Compliant

Signals - Compliant

Signals - Non Compliant

Transit Stops - Compliant

Transit Stops - Non Compliant

Railroad Crossings - Compliant

Railroad Crossings - Non Compliant

Accessible Parking - Compliant

Accessible Parking - Non Compliant

Curb Ramps - Adjacent

Island Curb Cuts - Adjacent

Signals - Adjacent

Transit Stops - Adjacent

Railroad Crossings - Adjacent

Accessible Parking - Adjacent

Heavings < 1" (Excluded)***Heavings ≥ 1" (Excluded)***Uneven Heaving (Excluded)***Heaving Clusters (Excluded)Sidewalk Joint Gap (Excluded)***Miscellaneous ObstructionMissing Sidewalk ObstructionOther ObstructionPole Post Hydrant ObstructionPonding ObstructionSidewalk Joint ObstructionSign ObstructionStorm Grate ObstructionTransit ObstructionTraffic ObstructionTree ObstructionUtility ObstructionVegetation Obstruction - LowVegetation Obstruction - OverheadSidewalk Collection PathAdjacent Sidewalk Collection PathBuried SidewalkSidewalk Not SurveyedMissing Sidewalk GapNo Sidewalk on Block

Heavings < 1"Heavings ≥ 1"Uneven HeavingHeaving ClustersSidewalk Joint GapCommercial EntranceResidential EntranceCommercial Entrance (within slope violation)Residential Entrance (within slope violation)

Cross Slope2 - 3%7.01 - 8%3.01 - 4%8.01 - 9%4.01 - 5%9.01 - 10%5.01% - 6%10.01 - 12%6.01 - 7%> 12%

Running Slope5 - 8.33%8.34% - 10%10.01 - 12.5%> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.