




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate								
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost					
1 Heavings less than 1"	7 EA	1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	3	3	\$ 6600.00	● Heavings < 1" (Excluded)***	● Heavings < 1"	● Sidewalk Joint Gap (Excluded)***	● Sidewalk Joint Gap	
2 Heavings 1" or greater	3 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"	● Miscellaneous Obstruction	● Commercial Entrance	
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	● Uneven Heaving (Excluded)***	● Uneven Heaving	● Missing Sidewalk Obstruction	● Residential Entrance	
4 Heaving Clusters	13.209 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	1	1	\$ 4150.00	— Heaving Clusters (Excluded)	— Heaving Clusters	■ Other Obstruction	■ Commercial Entrance (within slope violation)	
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap	■ Pole Post Hydrant Obstruction	■ Residential Entrance (within slope violation)	
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction	■ Ponding Obstruction		
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 10750.00	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction	■ Sidewalk Joint Obstruction	Cross Slope	
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Other Obstruction	■ Other Obstruction	■ Sign Obstruction	— 2 - 3%	— 7.01 - 8%
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	Corridor Total:			\$ 72330.00	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction	■ Storm Grate Obstruction	— 3.01 - 4%	— 8.01 - 9%
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	Curb Ramps - Compliant				■ Ponding Obstruction	■ Ponding Obstruction	■ Transit Obstruction	— 4.01 - 5%	— 9.01 - 10%
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	Curb Ramps - Non Compliant				■ Sidewalk Joint Obstruction	■ Sidewalk Joint Obstruction	■ Traffic Obstruction	— 5.01% - 6%	— 10.01 - 12%
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	Island Curb Cuts - Compliant				■ Sign Obstruction	■ Sign Obstruction	■ Tree Obstruction	— 6.01 - 7%	— > 12%
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	Island Curb Cuts - Non Compliant				■ Storm Grate Obstruction	■ Storm Grate Obstruction	■ Utility Obstruction		Running Slope
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	Signals - Compliant				■ Transit Obstruction	■ Transit Obstruction	■ Vegetation Obstruction - Low	— 5 - 8.33%	— 8.34% - 10%
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	Signals - Non Compliant				■ Traffic Obstruction	■ Traffic Obstruction	■ Vegetation Obstruction - Overhead	— 10.01 - 12.5%	— > 12.5%
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	Transit Stops - Compliant				■ Tree Obstruction	■ Tree Obstruction	— Sidewalk Collection Path		
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	Transit Stops - Non Compliant				■ Utility Obstruction	■ Utility Obstruction	— Adjacent Sidewalk Collection Path		
18 Vegetation Obstruction - Low	1 EA	18 Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00	Railroad Crossings - Compliant				■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low	— Buried Sidewalk		
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	Railroad Crossings - Non Compliant				■ Vegetation Obstruction - Overhead	■ Vegetation Obstruction - Overhead	— Sidewalk Not Surveyed		
20 Commercial Entrance	4 EA	20 Commercial Entrance (within slope violation)	4 EA	\$ 5000.00	\$ 20000.00	Accessible Parking - Compliant				— Sidewalk Collection Path	— Sidewalk Collection Path	— Missing Sidewalk Gap		
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00	Accessible Parking - Non Compliant				— Adjacent Sidewalk Collection Path	— Adjacent Sidewalk Collection Path	— No Sidewalk on Block		
22 Total Sidewalk Length Assessed	972.898 LF	22 Running Slope Violations**	6.438 SY	\$ 75.00	\$ 483.00					— Buried Sidewalk	— Buried Sidewalk			
23 Average Sidewalk Width	70 IN	23 Cross Slope Violations	524.394 SY	\$ 75.00	\$ 39330.00					— Sidewalk Not Surveyed	— Sidewalk Not Surveyed			
24 No Sidewalk on Block (Approx.)	0 LF	24 Running and Cross Slope Violations	21.565 SY	\$ 75.00	\$ 1617.00					— Missing Sidewalk Gap	— Missing Sidewalk Gap			
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00					— No Sidewalk on Block	— No Sidewalk on Block			
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00									
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00									
		Sidewalk SubTotal:			\$ 61580.00									
										*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.				
										**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.				
										***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.				