




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate								
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item	Description	Total Count	Non Compliant Count	Cost			
1	Heavings less than 1"	4 EA	1	Heavings less than 1"	2 EA	\$ 100.00	\$	200.00	Curb Ramps	2	2	\$	5050.00	
2	Heavings 1" or greater	1 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$	0.00	Island Curb Cuts	0	0	\$	0.00	
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00	Signal Push Buttons	0	0	\$	0.00	
4	Heaving Clusters	5.327 SY	4	Heaving Clusters	5.327 SY	\$ 75.00	\$	400.00	Transit Stops	0	0	\$	0.00	
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00	Railroad Crossings	0	0	\$	0.00	
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00	Accessible Parking Spaces	0	0	\$	0.00	
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00	Intersection SubTotal:			\$	5050.00	
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$	0.00						
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00						
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00						
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00						
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00						
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00						
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00						
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00						
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00						
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$	0.00						
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$	0.00						
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$	0.00						
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$	0.00						
21	Residential Entrance	2 EA	21	Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$	6000.00						
22	Total Sidewalk Length Assessed	297.219 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$	0.00						
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	49.173 SY	\$ 75.00	\$	3688.00						
24	No Sidewalk on Block (Approx.)	597.503 LF	24	Running and Cross Slope Violations	65.165 SY	\$ 75.00	\$	4887.00						
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00						
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00						
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$	0.00						
			Sidewalk SubTotal:				\$	15175.00						

Corridor Total:

\$ 20225.00

■ Curb Ramps - Compliant

■ Curb Ramps - Non Compliant

■ Island Curb Cuts - Compliant

■ Island Curb Cuts - Non Compliant

■ Signals - Compliant

■ Signals - Non Compliant

■ Transit Stops - Compliant

■ Transit Stops - Non Compliant

■ Railroad Crossings - Compliant

■ Railroad Crossings - Non Compliant

■ Accessible Parking - Compliant

■ Accessible Parking - Non Compliant

■ Curb Ramps - Adjacent

■ Island Curb Cuts - Adjacent

■ Signals - Adjacent

■ Transit Stops - Adjacent

■ Railroad Crossings - Adjacent

■ Accessible Parking - Adjacent

● Heavings < 1" (Excluded)***

● Heavings ≥ 1" (Excluded)***

● Uneven Heaving (Excluded)***

● Heaving Clusters (Excluded)

▲ Sidewalk Joint Gap (Excluded)***

■ Miscellaneous Obstruction

■ Missing Sidewalk Obstruction

■ Other Obstruction

■ Pole Post Hydrant Obstruction

■ Ponding Obstruction

■ Sidewalk Joint Obstruction

■ Sign Obstruction

■ Storm Grate Obstruction

■ Transit Obstruction

■ Traffic Obstruction

■ Tree Obstruction

■ Utility Obstruction

■ Vegetation Obstruction - Low

■ Vegetation Obstruction - Overhead

■ Sidewalk Collection Path

■ Adjacent Sidewalk Collection Path

■ Buried Sidewalk

■ Sidewalk Not Surveyed

■ Missing Sidewalk Gap

■ No Sidewalk on Block

Cross Slope

■ 2 - 3%

■ 3.01 - 4%

■ 4.01 - 5%

■ 5.01% - 6%

■ 6.01 - 7%

■ 7.01 - 8%

■ 8.01 - 9%

■ 9.01 - 10%

■ 10.01 - 12%

■ > 12%

Running Slope

■ 5 - 8.33%

■ 8.34% - 10%

■ 10.01 - 12.5%

■ > 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.