




ADA Survey Summary

Item Description	Quantity
1 Heavings less than 1"	1 EA
2 Heavings 1" or greater	0 EA
3 Uneven Heavings	0 EA
4 Heaving Clusters	0 SY
5 Sidewalk Joint Gaps	0 EA
6 Miscellaneous Obstruction	0 EA
7 Missing Sidewalk Obstruction	0 EA
8 Other Obstruction	0 EA
9 Pole Post Hydrant Obstruction	0 EA
10 Ponding Obstruction	0 EA
11 Sidewalk Joint Obstruction	0 EA
12 Sign Obstruction	0 EA
13 Storm Grate Obstruction	0 EA
14 Transit Obstruction	0 EA
15 Traffic Obstruction	0 EA
16 Tree Obstruction	0 EA
17 Utility Obstruction	0 EA
18 Vegetation Obstruction - Low	0 EA
19 Vegetation Obstruction - Overhead	1 EA
20 Commercial Entrance	0 EA
21 Residential Entrance	0 EA
22 Total Sidewalk Length Assessed	110.615 LF
23 Average Sidewalk Width	72 IN
24 No Sidewalk on Block (Approx.)	417.271 LF
25 Missing Sidewalk Gaps (Approx.)	313.243 LF
26 Poor Surface Condition (Approx.)	0 LF
27 Buried Sidewalk (Approx.)	0 LF

ADA Compliance Cost Estimate *

Item Description	Quantity	Unit Price	Item Cost
1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00
2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00
3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00
4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00
5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00
6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00
7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00
8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00
9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00
10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00
11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00
12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00
13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00
14 Transit Obstruction	0 EA	\$500.00	\$ 0.00
15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00
16 Tree Obstruction	0 EA	\$500.00	\$ 0.00
17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00
18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00
19 Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00
20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00
21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00
22 Running Slope Violations**	12.858 SY	\$ 75.00	\$ 964.00
23 Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00
24 Running and Cross Slope Violations	36.131 SY	\$ 75.00	\$ 2710.00
25 Missing Sidewalk Gaps (Approx.)	313.243 LF	\$ 41.67	\$ 12980.00
26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00
27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00

Intersection Inventory & Compliance Cost Estimate

Item Description	Total Count	Non Compliant Count	Cost
Curb Ramps	3	3	\$ 6300.00
Island Curb Cuts	0	0	\$ 0.00
Signal Push Buttons	3	3	\$ 2100.00
Transit Stops	0	0	\$ 0.00
Railroad Crossings	0	0	\$ 0.00
Accessible Parking Spaces	0	0	\$ 0.00
Intersection SubTotal:			\$ 8400.00

Corridor Total: \$ 25204.00

 Curb Ramps - Compliant	 Curb Ramps - Adjacent
 Curb Ramps - Non Compliant	
 Island Curb Cuts - Compliant	 Island Curb Cuts - Adjacent
 Island Curb Cuts - Non Compliant	
 Signals - Compliant	 Signals - Adjacent
 Signals - Non Compliant	
 Transit Stops - Compliant	 Transit Stops - Adjacent
 Transit Stops - Non Compliant	
 Railroad Crossings - Compliant	 Railroad Crossings - Adjacent
 Railroad Crossings - Non Compliant	
 Accessible Parking - Compliant	 Accessible Parking - Adjacent
 Accessible Parking - Non Compliant	

● Heavings < 1" (Excluded)***	● Heavings < 1"
● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"
● Uneven Heaving (Excluded)***	● Uneven Heaving
— Heaving Clusters (Excluded)	— Heaving Clusters
▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap
■ Miscellaneous Obstruction	◆ Commercial Entrance
■ Missing Sidewalk Obstruction	◆ Residential Entrance
■ Other Obstruction	⊕ Commercial Entrance (within slope violation)
■ Pole Post Hydrant Obstruction	⊕ Residential Entrance (within slope violation)
■ Ponding Obstruction	
■ Sidewalk Joint Obstruction	Cross Slope
■ Sign Obstruction	2 - 3% 7.01 - 8%
■ Storm Grate Obstruction	3.01 - 4% 8.01 - 9%
■ Transit Obstruction	4.01 - 5% 9.01 - 10%
■ Traffic Obstruction	5.01% - 6% 10.01 - 12%
■ Tree Obstruction	6.01 - 7% > 12%
■ Utility Obstruction	
■ Vegetation Obstruction - Low	Running Slope
■ Vegetation Obstruction - Overhead	5 - 8.33%
— Sidewalk Collection Path	8.34% - 10%
— Adjacent Sidewalk Collection Path	10.01 - 12.5%
— Buried Sidewalk	> 12.5%
— Sidewalk Not Surveyed	
— Missing Sidewalk Gap	
— No Sidewalk on Block	

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.