




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	4 EA	1	Heavings less than 1"	2 EA	\$ 100.00	\$	200.00	Curb Ramps	1	1	\$	1500.00
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$	0.00	Island Curb Cuts	0	0	\$	0.00
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00	Signal Push Buttons	0	0	\$	0.00
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$	0.00	Transit Stops	1	1	\$	2150.00
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00	Railroad Crossings	0	0	\$	0.00
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00	Accessible Parking Spaces	0	0	\$	0.00
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00	Intersection SubTotal:			\$	3650.00
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$	0.00	Corridor Total:				\$ 19565.00
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00	 Curb Ramps - Compliant	 Curb Ramps - Adjacent	● Heavings < 1" (Excluded)*** ● Heavings ≥ 1" (Excluded)*** ● Uneven Heaving (Excluded)*** Heaving Clusters (Excluded) ▲ Sidewalk Joint Gap (Excluded)*** ■ Miscellaneous Obstruction ■ Missing Sidewalk Obstruction ■ Other Obstruction ■ Pole Post Hydrant Obstruction ■ Ponding Obstruction ■ Sidewalk Joint Obstruction ■ Sign Obstruction ■ Storm Grate Obstruction ■ Transit Obstruction ■ Traffic Obstruction ■ Tree Obstruction ■ Utility Obstruction ■ Vegetation Obstruction - Low ■ Vegetation Obstruction - Overhead ■ Sidewalk Collection Path ■ Adjacent Sidewalk Collection Path ■ Buried Sidewalk ■ Sidewalk Not Surveyed ■ Missing Sidewalk Gap ■ No Sidewalk on Block Cross Slope 2 - 3% 3.01 - 4% 4.01 - 5% 5.01% - 6% 6.01 - 7% 7.01 - 8% 8.01 - 9% 9.01 - 10% 10.01 - 12% > 12% Running Slope 5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5%		
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00	 Curb Ramps - Non Compliant	 Island Curb Cuts - Adjacent			
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00	 Island Curb Cuts - Compliant	 Island Curb Cuts - Adjacent			
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00	 Island Curb Cuts - Non Compliant	 Signals - Adjacent			
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00	 Signals - Compliant	 Signals - Adjacent			
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00	 Signals - Non Compliant	 Transit Stops - Adjacent			
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00	 Transit Stops - Compliant	 Transit Stops - Adjacent			
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00	 Transit Stops - Non Compliant	 Railroad Crossings - Adjacent			
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$	0.00	 Railroad Crossings - Compliant	 Railroad Crossings - Adjacent			
18	Vegetation Obstruction - Low	1 EA	18	Vegetation Obstruction - Low	1 EA	\$150.00	\$	150.00	 Railroad Crossings - Non Compliant	 Accessible Parking - Adjacent			
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$	0.00	 Accessible Parking - Compliant	 Accessible Parking - Adjacent			
20	Commercial Entrance	1 EA	20	Commercial Entrance (within slope violation)	1 EA	\$ 5000.00	\$	5000.00	 Accessible Parking - Non Compliant				
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$	0.00					
22	Total Sidewalk Length Assessed	351.334 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$	0.00					
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	107.631 SY	\$ 75.00	\$	8072.00					
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	33.234 SY	\$ 75.00	\$	2493.00					
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00					
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00					
27	Buried Sidewalk (Approx.)	253.639 LF	27	Buried Sidewalk (Approx.)	253.639 LF	\$ 41.67	\$	10560.00					
			Sidewalk SubTotal:			\$		15915.00	*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.				
									**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.				
									***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.				