




ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate				Legend								
Item	Description	Quantity		Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost							
1	Heavings less than 1"	16 EA		1	Heavings less than 1"	5 EA	\$ 100.00	\$ 500.00	Curb Ramps		2	2	\$ 6400.00	●	Heavings < 1" (Excluded)***	●	Heavings < 1"			
2	Heavings 1" or greater	3 EA		2	Heavings 1" or greater	1 EA	\$ 400.00	\$ 400.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"			
3	Uneven Heavings	2 EA		3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	●	Uneven Heaving			
4	Heaving Clusters	8.764 SY		4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		2	2	\$ 6300.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters			
5	Sidewalk Joint Gaps	0 EA		5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap			
6	Miscellaneous Obstruction	0 EA		6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction	◆	Commercial Entrance			
7	Missing Sidewalk Obstruction	0 EA		7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 12700.00	■	Missing Sidewalk Obstruction	◆	Residential Entrance			
8	Other Obstruction	0 EA		8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 58159.00	■	Other Obstruction	⊕	Commercial Entrance (within slope violation)			
9	Pole Post Hydrant Obstruction	0 EA		9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00						■	Pole Post Hydrant Obstruction	⊕	Residential Entrance (within slope violation)			
10	Ponding Obstruction	0 EA		10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00						■	Ponding Obstruction		Cross Slope			
11	Sidewalk Joint Obstruction	0 EA		11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00						■	Sidewalk Joint Obstruction	■	2 - 3%	■	7.01 - 8%	
12	Sign Obstruction	0 EA		12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00						■	Sign Obstruction	■	3.01 - 4%	■	8.01 - 9%	
13	Storm Grate Obstruction	0 EA		13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00						■	Storm Grate Obstruction	■	4.01 - 5%	■	9.01 - 10%	
14	Transit Obstruction	0 EA		14	Transit Obstruction	0 EA	\$500.00	\$ 0.00						■	Transit Obstruction	■	5.01% - 6%	■	10.01 - 12%	
15	Traffic Obstruction	0 EA		15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00						■	Traffic Obstruction	■	6.01 - 7%	■	> 12%	
16	Tree Obstruction	0 EA		16	Tree Obstruction	0 EA	\$500.00	\$ 0.00						■	Tree Obstruction		Running Slope			
17	Utility Obstruction	0 EA		17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00						■	Utility Obstruction	■	5 - 8.33%			
18	Vegetation Obstruction - Low	0 EA		18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Low	■	8.34% - 10%			
19	Vegetation Obstruction - Overhead	0 EA		19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Overhead	■	10.01 - 12.5%			
20	Commercial Entrance	4 EA		20	Commercial Entrance (within slope violation)	4 EA	\$ 5000.00	\$ 20000.00						—	Sidewalk Collection Path	—	> 12.5%			
21	Residential Entrance	0 EA		21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00						—	Adjacent Sidewalk Collection Path					
22	Total Sidewalk Length Assessed	767.801 LF		22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00						—	Buried Sidewalk					
23	Average Sidewalk Width	60 IN		23	Cross Slope Violations	321.457 SY	\$ 75.00	\$ 24109.00						—	Sidewalk Not Surveyed					
24	No Sidewalk on Block (Approx.)	887.416 LF		24	Running and Cross Slope Violations	5.994 SY	\$ 75.00	\$ 450.00						—	Missing Sidewalk Gap					
25	Missing Sidewalk Gaps (Approx.)	0 LF		25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00						—	No Sidewalk on Block					
26	Poor Surface Condition (Approx.)	0 LF		26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00												
27	Buried Sidewalk (Approx.)	501.094 LF		27	Buried Sidewalk (Approx.)	501.094 LF	\$ 41.67	\$ 20900.00												
				Sidewalk SubTotal:				\$ 45459.00												
										*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.										
										**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.										
										***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.										