




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate									
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost			
1	Heavings less than 1"	5 EA	1	Heavings less than 1"	5 EA	\$ 100.00	\$ 500.00	Curb Ramps		7	7	\$ 17300.00		Heavings < 1" (Excluded)***	
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00		Heavings ≥ 1" (Excluded)***	
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00		Uneven Heaving (Excluded)***	
4	Heaving Clusters	2.22 SY	4	Heaving Clusters	2.22 SY	\$ 75.00	\$ 167.00	Transit Stops		0	0	\$ 0.00		Heaving Clusters (Excluded)	
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00		Sidewalk Joint Gap (Excluded)***	
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00		Miscellaneous Obstruction	
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 17300.00		Missing Sidewalk Obstruction	
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:					\$ 27222.00		Other Obstruction
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00		Curb Ramps - Compliant			Curb Ramps - Adjacent		Pole Post Hydrant Obstruction	
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00		Curb Ramps - Non Compliant			Island Curb Cuts - Adjacent		Ponding Obstruction	
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00		Island Curb Cuts - Compliant			Island Curb Cuts - Adjacent		Sidewalk Joint Obstruction	
12	Sign Obstruction	1 EA	12	Sign Obstruction	1 EA	\$ 150.00	\$ 150.00		Island Curb Cuts - Non Compliant			Signals - Adjacent		Sign Obstruction	
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00		Signals - Compliant			Transit Stops - Adjacent		Storm Grate Obstruction	
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00		Signals - Non Compliant			Transit Stops - Adjacent		Transit Obstruction	
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00		Transit Stops - Compliant			Transit Stops - Adjacent		Traffic Obstruction	
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00		Transit Stops - Non Compliant			Transit Stops - Adjacent		Tree Obstruction	
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00		Railroad Crossings - Compliant			Railroad Crossings - Adjacent		Utility Obstruction	
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00		Railroad Crossings - Non Compliant			Railroad Crossings - Adjacent		Vegetation Obstruction - Low	
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00		Accessible Parking - Compliant			Accessible Parking - Adjacent		Vegetation Obstruction - Overhead	
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00		Accessible Parking - Non Compliant					Sidewalk Collection Path	
21	Residential Entrance	3 EA	21	Residential Entrance (within slope violation)	1 EA	\$ 3000.00	\$ 3000.00							Adjacent Sidewalk Collection Path	
22	Total Sidewalk Length Assessed	399.156 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00							Buried Sidewalk	
23	Average Sidewalk Width	60 IN	23	Cross Slope Violations	29.161 SY	\$ 75.00	\$ 2187.00							Sidewalk Not Surveyed	
24	No Sidewalk on Block (Approx.)	378.061 LF	24	Running and Cross Slope Violations	52.242 SY	\$ 75.00	\$ 3918.00							Missing Sidewalk Gap	
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00							No Sidewalk on Block	
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00								
			Sidewalk SubTotal:				\$ 9922.00								
														*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.	
														**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.	