



| ADA Survey Summary                   |            |  | ADA Compliance Cost Estimate *                   |           |            |           |
|--------------------------------------|------------|--|--------------------------------------------------|-----------|------------|-----------|
| Item Description                     | Quantity   |  | Item Description                                 | Quantity  | Unit Price | Item Cost |
| 1 Heavings less than 1"              | 2 EA       |  | 1 Heavings less than 1"                          | 1 EA      | \$ 100.00  | \$ 100.00 |
| 2 Heavings 1" or greater             | 0 EA       |  | 2 Heavings 1" or greater                         | 0 EA      | \$ 400.00  | \$ 0.00   |
| 3 Uneven Heavings                    | 0 EA       |  | 3 Uneven Heavings                                | 0 EA      | \$ 400.00  | \$ 0.00   |
| 4 Heaving Clusters                   | 1.775 SY   |  | 4 Heaving Clusters                               | 0 SY      | \$ 75.00   | \$ 0.00   |
| 5 Sidewalk Joint Gaps                | 0 EA       |  | 5 Sidewalk Joint Gaps                            | 0 EA      | \$ 200.00  | \$ 0.00   |
| 6 Miscellaneous Obstruction          | 0 EA       |  | 6 Miscellaneous Obstruction                      | 0 EA      | \$ 1500.00 | \$ 0.00   |
| 7 Missing Sidewalk Obstruction       | 0 EA       |  | 7 Missing Sidewalk Obstruction                   | 0 EA      | \$ 200.00  | \$ 0.00   |
| 8 Other Obstruction                  | 0 EA       |  | 8 Other Obstruction                              | 0 EA      | \$ 500.00  | \$ 0.00   |
| 9 Pole Post Hydrant Obstruction      | 0 EA       |  | 9 Pole Post Hydrant Obstruction                  | 0 EA      | \$ 5000.00 | \$ 0.00   |
| 10 Ponding Obstruction               | 0 EA       |  | 10 Ponding Obstruction                           | 0 EA      | \$ 400.00  | \$ 0.00   |
| 11 Sidewalk Joint Obstruction        | 0 EA       |  | 11 Sidewalk Joint Obstruction                    | 0 EA      | \$ 100.00  | \$ 0.00   |
| 12 Sign Obstruction                  | 0 EA       |  | 12 Sign Obstruction                              | 0 EA      | \$ 150.00  | \$ 0.00   |
| 13 Storm Grate Obstruction           | 0 EA       |  | 13 Storm Grate Obstruction                       | 0 EA      | \$700.00   | \$ 0.00   |
| 14 Transit Obstruction               | 0 EA       |  | 14 Transit Obstruction                           | 0 EA      | \$500.00   | \$ 0.00   |
| 15 Traffic Obstruction               | 0 EA       |  | 15 Traffic Obstruction                           | 0 EA      | \$2000.00  | \$ 0.00   |
| 16 Tree Obstruction                  | 0 EA       |  | 16 Tree Obstruction                              | 0 EA      | \$500.00   | \$ 0.00   |
| 17 Utility Obstruction               | 0 EA       |  | 17 Utility Obstruction                           | 0 EA      | \$1500.00  | \$ 0.00   |
| 18 Vegetation Obstruction - Low      | 0 EA       |  | 18 Vegetation Obstruction - Low                  | 0 EA      | \$150.00   | \$ 0.00   |
| 19 Vegetation Obstruction - Overhead | 0 EA       |  | 19 Vegetation Obstruction - Overhead             | 0 EA      | \$150.00   | \$ 0.00   |
| 20 Commercial Entrance               | 0 EA       |  | 20 Commercial Entrance (within slope violation)  | 0 EA      | \$ 5000.00 | \$ 0.00   |
| 21 Residential Entrance              | 0 EA       |  | 21 Residential Entrance (within slope violation) | 0 EA      | \$ 3000.00 | \$ 0.00   |
| 22 Total Sidewalk Length Assessed    | 104.415 LF |  | 22 Running Slope Violations**                    | 0 SY      | \$ 75.00   | \$ 0.00   |
| 23 Average Sidewalk Width            | 48 IN      |  | 23 Cross Slope Violations                        | 11.583 SY | \$ 75.00   | \$ 869.00 |
| 24 No Sidewalk on Block (Approx.)    | 0 LF       |  | 24 Running and Cross Slope Violations            | 0 SY      | \$ 75.00   | \$ 0.00   |
| 25 Missing Sidewalk Gaps (Approx.)   | 0 LF       |  | 25 Missing Sidewalk Gaps (Approx.)               | 0 LF      | \$ 41.67   | \$ 0.00   |
| 26 Poor Surface Condition (Approx.)  | 0 LF       |  | 26 Poor Surface Condition (Approx.)              | 0 LF      | \$ 41.67   | \$ 0.00   |
| 27 Buried Sidewalk (Approx.)         | 0 LF       |  | 27 Buried Sidewalk (Approx.)                     | 0 LF      | \$ 41.67   | \$ 0.00   |
|                                      |            |  | Sidewalk SubTotal:                               |           |            | \$ 969.00 |

| Intersection Inventory & Compliance Cost Estimate |             |                     |            |
|---------------------------------------------------|-------------|---------------------|------------|
| Item Description                                  | Total Count | Non Compliant Count | Cost       |
| Curb Ramps                                        | 2           | 2                   | \$ 4700.00 |
| Island Curb Cuts                                  | 0           | 0                   | \$ 0.00    |
| Signal Push Buttons                               | 0           | 0                   | \$ 0.00    |
| Transit Stops                                     | 0           | 0                   | \$ 0.00    |
| Railroad Crossings                                | 0           | 0                   | \$ 0.00    |
| Accessible Parking Spaces                         | 0           | 0                   | \$ 0.00    |
| Intersection SubTotal:                            |             |                     | \$ 4700.00 |

**Corridor Total:** \$ 5669.00

|                                                                                                                          |                                                                                                                     |
|--------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|
|  Curb Ramps - Compliant             |  Curb Ramps - Adjacent         |
|  Curb Ramps - Non Compliant         |                                                                                                                     |
|  Island Curb Cuts - Compliant       |  Island Curb Cuts - Adjacent   |
|  Island Curb Cuts - Non Compliant   |                                                                                                                     |
|  Signals - Compliant                |  Signals - Adjacent            |
|  Signals - Non Compliant            |                                                                                                                     |
|  Transit Stops - Compliant          |  Transit Stops - Adjacent      |
|  Transit Stops - Non Compliant      |                                                                                                                     |
|  Railroad Crossings - Compliant     |  Railroad Crossings - Adjacent |
|  Railroad Crossings - Non Compliant |                                                                                                                     |
|  Accessible Parking - Compliant     |  Accessible Parking - Adjacent |
|  Accessible Parking - Non Compliant |                                                                                                                     |

- Obstructions**

  - Heavings < 1" (Excluded)\*\*\*
  - Heavings ≥ 1" (Excluded)\*\*\*
  - Uneven Heaving (Excluded)\*\*\*
  - Heaving Clusters (Excluded)
  - ▲ Sidewalk Joint Gap (Excluded)\*\*\*
  - Miscellaneous Obstruction
  - Missing Sidewalk Obstruction
  - Other Obstruction
  - Pole Post Hydrant Obstruction
  - Ponding Obstruction
  - Sidewalk Joint Obstruction
  - Sign Obstruction
  - Storm Grate Obstruction
  - Transit Obstruction
  - Traffic Obstruction
  - Tree Obstruction
  - Utility Obstruction
  - Vegetation Obstruction - Low
  - Vegetation Obstruction - Overhead
  - Sidewalk Collection Path
  - Adjacent Sidewalk Collection Path
  - Buried Sidewalk
  - Sidewalk Not Surveyed
  - Missing Sidewalk Gap
  - No Sidewalk on Block

**Slopes**

**Cross Slope**

  - 2 - 3%
  - 3.01 - 4%
  - 4.01 - 5%
  - 5.01% - 6%
  - 6.01 - 7%
  - 7.01 - 8%
  - 8.01 - 9%
  - 9.01 - 10%
  - 10.01 - 12%
  - > 12%

**Running Slope**

  - 5 - 8.33%
  - 8.34% - 10%
  - 10.01 - 12.5%
  - > 12.5%

\*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.