

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 17901	Main Street: COLWICK_RD	Cross Street: N_SHARON_AMITY_RD	Location: NE
ADA ID: 01788C27742A	Ramp Type: ParaDiag	Initial Pass/Fail: Pass	Overall Compliance: No
Severity Score: 0.25			
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

R304.5.3, R304.2.1

Street 1 Name COLWICK RD
 Stop Condition-Street 1 StopSign
 Street 2 Name N SHARON AMITY RD
 Stop Condition-Street 2 None

Total Cost: \$ 3200.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	60.0	N/A	Ramp Length RT (in)	58.0
Yes	Ramp Width LT (in)	58.0	Yes	Ramp Width RT (in)	60.0
Yes	Ramp Slope LT (%)	8.0	Yes	Ramp Slope RT (%)	6.6
Yes	Ramp XSlope LT (%)	1.8	No	Ramp XSlope RT (%)	3.3
No	Landing Length (in)	59.0	Yes	DWS Provided?	Yes
No	Landing Width (in)	46.5	Yes	DWS Contrast?	Yes
Yes	Landing Slope (%)	0.4	Yes	DWS Length (in)	24.0
Yes	Landing X Slope (%)	0.7	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	Yes	Yes	DWS Offset (in)	1.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	0.3
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.1
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To SW		X Walk 2 Direction	To SE
N/A	X Walk 1 Width (in)	112.0	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	0.7		X Walk 2 Slope (%)	2.3
	X Walk 1 X Slope (%)	0.2		X Walk 2 X Slope (%)	0.5
Yes	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	1.1	N/A	Clear Space?	Yes
	Road X Slope (%)	2.0	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	6.7

