

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 17610 Main Street: EMORY LN Cross Street: N SHARON AMITY RD Location: NW **Overall Compliance: No Severity Score:** ADA ID: 02477393CE86 Ramp Type: PerpDiag Initial Pass/Fail: Fail 26.25

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



N SHARON AMITY RD Street 1 Name Stop Condition-Street 2 None **EMORY LN** Street 2 Name Stop Condition-Street 1 StopSign Possible Solutions: Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Surveyor Notes: N/A PROW/ADA: Not Found, R304.2.2, R304.5.3

Total Cost: 3200.00

Compliance Description Data Compliance Description Data No N/A Ramp Length (in) 33.0 Ramp Slope (%) 14.4 No Ramp XSlope (%) Yes Ramp Width (in) 48.0 4.1 N/A N/A Flare Type LT N/A Flare Type RT N/A N/A N/A N/A Flare Slope RT (%) N/A Flare Slope LT (%) N/A Flare Traversable LT? N/A N/A Flare Traversable RT? N/A N/A N/A N/A **DWS Provided?** N/A Landing Length (in) N/A Landing Width (in) N/A N/A **DWS Contrast?** N/A N/A N/A N/A Landing Slope (%) DWS Length (in) N/A N/A Landing X Slope (%) N/A N/A DWS Full Width? N/A N/A Landing Curb? (Y/N) N/A N/A DWS Offset (in) N/A N/A N/A Shared Landing? N/A **Gutter Ponding?** N/A N/A Gutter Slope (%) N/A N/A Gutter Lip Ht (in) N/A N/A Gutter X Slope (%) N/A N/A Painted X Walk1? No N/A Painted X Walk2? No X Walk 1 Direction To S X Walk 2 Direction To E N/A N/A X Walk 2 Width (in) X Walk 1 Width (in) N/A X Walk 1 Slope (%) 5.3 X Walk 2 Slope (%) 0.1 X Walk 1 X Slope (%) 2.6 X Walk 2 X Slope (%) 4.8 N/A N/A N/A Ramp inside XWalk2? N/A Ramp inside XWalk1? Road Slope (%) 4.8 N/A Clear Space? N/A N/A Road X Slope (%) 3.3 Clear Space to XWalk (in) N/A N/A N/A N/A Any Obstructions? Storm Grate/Utility Hazard? N/A **Obstruction Type** Storm Grate/Utility Type N/A N/A

Yes

Surface Condition? (G/P)

Good





