

Access Compliance Report Public Rights-of-Way (Curb Ramps)



								L C	NU.4/	
Intersection ID: 14970	Main Street: ATHERTON_ST			Cross Street: MARSHALL_PL				Location:	NW	
ADA ID: 0446F4CD8071	Ramp Type: Perp			Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	12.5	
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance						
	1.276.000	Possible Solutions:		Compliance Description Data Comp			liance Description Data			
		Remove & Replace Entire Ramp		N/A	Ramp Length (in)	96.0	No	Ramp Slope (%)	9.4	
				Yes	Ramp Width (in)	71.0	Yes	Ramp XSlope (%)	1.4	
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
CUL PROPAGE I	10 A C 10			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
The second secon		1		N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
	4/1	<u>,</u>		N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
		Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
E Color	X	N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
	1. 10			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
the second se				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
A A A	1			N/A	Shared Landing?	N/A				
and a state of the		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
A STATE AND A STAT	1 1	Not Found, R304.2.2		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
	1 salters			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A	
	M.				X Walk 1 Direction	To NE		X Walk 2 Direction	N/A	
	J A			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
Street 1 Name AT	HERTON ST				X Walk 1 Slope (%)	1.5		X Walk 2 Slope (%)	N/A	
Stop Condition-Street 2	None				X Walk 1 X Slope (%)	1.0		X Walk 2 X Slope (%)	N/A	
Street 2 Name	N/A			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
Stop Condition-Street 1	N/A				Road Slope (%)	N/A	N/A	Clear Space?	N/A	
					Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
		Total Cost: \$	1850.00		Obstruction Type			Storm Grate/Utility Type		
						N/A			N/A	

Yes Surface Condition? (G/P)

Good

