


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 48464	Main Street: TARPWAY_RD	Cross Street: PETE_BROWN_RD	Location: SE
ADA ID: 04DC8B7CB81E	Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 1.25	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance						
	Possible Solutions:							
	Remove & Replace Entire Ramp.							
	Surveyor Notes:							
	N/A							
	PROW/ADA:							
	R304.5.3							
	Street 1 Name	TARPWAY RD						
	Stop Condition-Street 1	StopSign						
	Street 2 Name	N/A						
	Stop Condition-Street 2	N/A						
Total Cost:		\$	1600.00					
		Compliance	Description	Data	Compliance	Description	Data	
		N/A	Ramp Length (in)	32.0	N/A	Grade Break?	N/A	
		Yes	Ramp Width (in)	71.0	N/A	Grade Break Slope (%)	0.0	
		Yes	Ramp Slope (%)	7.6	N/A	Grade Break XSlope (%)	0.0	
		No	Ramp XSlope (%)	3.6				
		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
		N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	0.0	
		N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
		N/A	Landing Length (in)	0.0	N/A	DWS Provided?	N/A	
		N/A	Landing Width (in)	0.0	N/A	DWS Contrast?	N/A	
		N/A	Landing Slope (%)	0.0	N/A	DWS Length (in)	N/A	
		N/A	Landing X Slope (%)	0.0	N/A	DWS Full Width?	N/A	
		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset LT (in)	N/A	
		N/A	Shared Landing?	N/A	N/A	DWS Offset RT (in)	N/A	
		N/A	Gutter Ponding?	0.0	N/A	Gutter Slope (%)	N/A	
		N/A	Gutter Lip Ht (in)	0.0	N/A	Gutter X Slope (%)	N/A	
		N/A	Painted X Walk1?	No		Road Slope (%)	1.8	
			X Walk 1 Direction	To W		Road X Slope (%)	3.2	
			X Walk 1 Width (in)	N/A		Clear Space?	N/A	
			X Walk 1 Slope (%)	1.8	N/A	Clear Space to XWalk (in)	N/A	
			X Walk 1 X Slope (%)	3.2	N/A	Storm Grate/Utility Hazard?	N/A	
		N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type		
		N/A	Any Obstructions?	N/A			N/A	
			Obstruction Type		Yes	Surface Condition? (G/P)	Good	
				N/A	N/A	Curb Slope (%)	N/A	

