


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 29372	Main Street: EULER_WY	Cross Street: WILSON_GLEN_DR	Location: SW
ADA ID: 0663F1DAE931	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 21.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	96.0	Yes	Ramp Slope (%)	6.3
			No	Ramp Width (in)	47.0	No	Ramp XSlope (%)	6.3
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
	Surveyor Notes: N/A		N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A			Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
PROW/ADA: R304.5.1, R304.5.3		N/A	Shared Landing?	N/A				
		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No	
			X Walk 1 Direction	To E		X Walk 2 Direction	To N	
		N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
			X Walk 1 Slope (%)	6.7		X Walk 2 Slope (%)	1.3	
			X Walk 1 X Slope (%)	0.2		X Walk 2 X Slope (%)	9.4	
		N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
			Road Slope (%)	6.3	N/A	Clear Space?	N/A	
Total Cost: \$ 3200.00			Road X Slope (%)	5.1	N/A	Clear Space to XWalk (in)	N/A	
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
			Obstruction Type			Storm Grate/Utility Type		
				N/A			N/A	
					Yes	Surface Condition? (G/P)	Good	

Street 1 Name FULER WY

Stop Condition-Street 2 StopSign

Street 2 Name WILSON GLEN DR

Stop Condition-Street 1 None

Total Cost: \$ 3200.00

