


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 3817		Main Street: BROWNE'S_FERRY_RD	Cross Street: W_SUGAR_CREEK_RD	Location:	NW
ADA ID: 084AB3AB144B		Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score: 6.5
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
		Possible Solutions:	Compliance	Description	Data
		Remove & Replace Entire Ramp.	N/A	Ramp Length (in)	46.0
Surveyor Notes: N/A		PROW/ADA: R304.2.1, R304.2.2-Perp, R304.3.2-Para, R304.5.3, R304.5.2, R305.1.4, R305.2	Yes	Ramp Width (in)	86.0
			Yes	Ramp Slope (%)	6.7
			Yes	Ramp XSlope (%)	2.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	7.8
			N/A	Flare Traversable LT?	No
			No	Landing Length (in)	45.0
			No	Landing Width (in)	47.5
			No	Landing Slope (%)	4.3
			No	Landing X Slope (%)	2.3
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	No
			Yes	Gutter Ponding?	No
			Yes	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To E
				X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	1.7
				X Walk 1 X Slope (%)	2.1
			N/A	Ramp inside XWalk1?	N/A
			Yes	Any Obstructions?	No
				Obstruction Type	
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	6.5
Street 1 Name Stop Condition-Street 1 Street 2 Name Stop Condition-Street 2		W SUGAR CREEK RD None N/A N/A			
		Total Cost:	\$	1600.00	

