



# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 49390	Main Street: DISTRICT_DR	Cross Street: SHORTHORN_ST	Location: NW
ADA ID: 08604292372E	Ramp Type: Combination1	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 46.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		<b>Compliance</b>	<b>Description</b>	<b>Data</b>
	<b>Remove &amp; Replace Entire Ramp.</b>		<b>N/A</b>	Ramp Length LT (in)	<b>42.0</b>
			<b>Yes</b>	Ramp Width LT (in)	<b>60.0</b>
			<b>No</b>	Ramp Slope LT (%)	<b>11.1</b>
			<b>Yes</b>	Ramp XSlope LT (%)	<b>1.8</b>
			<b>N/A</b>	Ramp Length (in)	<b>90.0</b>
			<b>No</b>	Ramp Width (in)	<b>46.5</b>
			<b>N/A</b>	Flare Type LT	<b>N/A</b>
			<b>N/A</b>	Flare Slope LT (%)	<b>N/A</b>
			<b>N/A</b>	Flare Traversable LT?	<b>N/A</b>
<p>Surveyor Notes:</p> <p><b>N/A</b></p>			<b>N/A</b>	Flare Type RT	<b>N/A</b>
			<b>N/A</b>	Flare Slope RT (%)	<b>N/A</b>
			<b>N/A</b>	Flare Traversable RT?	<b>N/A</b>
			<b>N/A</b>	DWS Provided?	<b>N/A</b>
			<b>N/A</b>	DWS Contrast?	<b>N/A</b>
			<b>N/A</b>	DWS Length (in)	<b>N/A</b>
			<b>N/A</b>	DWS Full Width?	<b>N/A</b>
			<b>N/A</b>	DWS Offset (in)	<b>N/A</b>
			<b>N/A</b>	Gutter Slope (%)	<b>N/A</b>
			<b>N/A</b>	Gutter X Slope (%)	<b>N/A</b>
<p>PROW/ADA:</p> <p><b>Not Found, R304.5.1, R304.5.3, R304.3.2</b></p>			<b>N/A</b>	Painted X Walk1?	<b>No</b>
				X Walk 1 Direction	<b>To E</b>
				X Walk 1 Width (in)	<b>N/A</b>
				X Walk 1 Slope (%)	<b>0.8</b>
				X Walk 1 X Slope (%)	<b>7.3</b>
			<b>N/A</b>	Ramp inside XWalk1?	<b>N/A</b>
			<b>N/A</b>	Ramp inside XWalk2?	<b>N/A</b>
			<b>N/A</b>	Clear Space?	<b>N/A</b>
			<b>N/A</b>	Clear Space to XWalk (in)	<b>N/A</b>
			<b>N/A</b>	Any Obstruction?	<b>N/A</b>
				Obstruction Type	<b>N/A</b>
				Storm Grate/Utility Hazard?	<b>N/A</b>
				Storm Grate/Utility Type	<b>N/A</b>
			<b>Yes</b>	Surface Condition? (G/P)	<b>Good</b>
				Curb Slope (%)	<b>9.2</b>
Total Cost:		\$ 1800.00	<b>N/A</b>		