


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 47972	Main Street: ALHAMBRA_LN	Cross Street: SOUTH_CREEK_RD	Location: W
ADA ID: 095616CF1E1B	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 10	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance			
	Possible Solutions:	Compliance	Description	Data	
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.	N/A	Ramp Length (in)	47.0	Yes
		No	Ramp Width (in)	46.0	No
		N/A	Flare Type LT	N/A	N/A
		N/A	Flare Slope LT (%)	N/A	N/A
		N/A	Flare Traversable LT?	N/A	N/A
		N/A	Landing Length (in)	N/A	N/A
		N/A	Landing Width (in)	N/A	N/A
		N/A	Landing Slope (%)	N/A	N/A
		N/A	Landing X Slope (%)	N/A	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.5.1, R304.5.3</p>		N/A	Flare Type RT	N/A	N/A
		N/A	Flare Slope RT (%)	N/A	N/A
		N/A	Flare Traversable RT?	N/A	N/A
		N/A	DWS Provided?	N/A	N/A
		N/A	DWS Contrast?	N/A	N/A
		N/A	DWS Length (in)	N/A	N/A
		N/A	DWS Full Width?	N/A	N/A
		N/A	DWS Offset (in)	N/A	N/A
		N/A	Shared Landing?	N/A	N/A
		N/A	Gutter Ponding?	N/A	N/A
		N/A	Gutter Lip Ht (in)	N/A	N/A
		N/A	Painted X Walk1?	No	N/A
			X Walk 1 Direction	To SE	
		N/A	X Walk 1 Width (in)	N/A	N/A
			X Walk 1 Slope (%)	2.4	
			X Walk 1 X Slope (%)	4.1	
		N/A	Ramp inside XWalk1?	N/A	N/A
			Road Slope (%)	2.3	N/A
			Road X Slope (%)	3.0	N/A
		N/A	Any Obstructions?	N/A	N/A
Total Cost:		\$	3200.00		
			Obstruction Type		
				N/A	N/A
				Yes	Surface Condition? (G/P)
					Good

