cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 29986	rsection ID: 29986 Main Street: SECRET_GARDEN_LN				Cross Street: WINDING_RIVER_DR				W
ADA ID: 0AA55CE1C36B Ramp Type: PerpDiag				Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	13.75
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
	Possible Solutions:					Data Compliance Description		Data	
		Remove & Replace Curb Ra	amp With	N/A	Ramp Length (in)	46.0	No	Ramp Slope (%)	8.4
		Two New Directional Ramp	-	Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	4.2
		Equivalent.		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
		1		N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
TINDING AWAR, DR.				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
		Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
a second second second			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
			N/A	Shared Landing?	N/A				
		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
		Not Found, R304.2.2, R304.	5.3	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
		,,,,,		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
					X Walk 1 Direction	To SE		X Walk 2 Direction	To NE
				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name SECRET G	ARDEN LN	-			X Walk 1 Slope (%)	7.3		X Walk 2 Slope (%)	7.1
Stop Condition-Street 2	StopSign				X Walk 1 X Slope (%)	3.1		X Walk 2 X Slope (%)	10.7
Street 2 Name WINDING	RIVER DR			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	None				Road Slope (%)	3.4	N/A	Clear Space?	N/A
					Road X Slope (%)	9.9	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost:	\$ 3200.00		Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A



