

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 26449 Main Street: MANNINGTON DR Cross Street: MCKENZIE_CREEK_DR Location: NW ADA ID: 0BB76E6F4E4D Ramp Type: Perp Initial Pass/Fail: Fail **Overall Compliance: No Severity Score:** 10

Codes/Mitigation Info/Possible Solution



MCKENZIE CREEK DR Street 1 Name Stop Condition-Street 2 None Street 2 Name N/A Stop Condition-Street 1 N/A

Possible Solutions: Remove & Replace Entire Ramp. Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1

Total Cost: 1850.00

Field Measurements/Component Compliance						
Comp	liance Description	Data	Comp	liance	Description	Data
N/A	Ramp Length (in)	94.0	Yes	Ramp	Slope (%)	5.0
No	Ramp Width (in)	43.5	Yes	Ramp	XSlope (%)	2.8
N/A	Flare Type LT	N/A	N/A	A Flare Type RT		N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare	Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare	Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS	Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS	Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS	Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS	Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS	Offset (in)	N/A
N/A	Shared Landing?	N/A				
N/A	Gutter Ponding?	N/A	N/A	Gutte	er Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutte	r X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Paint	ed X Walk2?	N/A
	X Walk 1 Direction	То Е		X Wa	lk 2 Direction	N/A
N/A	X Walk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A
	X Walk 1 Slope (%)	1.8		X Wa	lk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	3.0		X Wa	lk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ram	inside XWalk2?	N/A
	Road Slope (%)	3.0	N/A	Clear	Space?	N/A
	Road X Slope (%)	1.8	N/A	Clear	Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storn	n Grate/Utility Hazard?	N/A
	Obstruction Type			Storn	n Grate/Utility Type	
		N/A				N/A
			Yes	Surfa	ce Condition? (G/P)	Good





