

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: N/A Main Street: YORK_CENTER Cross Street: N/A Location:

Overall Compliance: No Severity Score: 15.25 **ADA ID: 0BC4A68B4E3E** Ramp Type: Perp Initial Pass/Fail: Pass

Codes/Mitigation Info/Possible Solution



THE RESERVE OF THE PARTY OF THE	
Street 1 Name	REMOUNT RD
Stop Condition-Street 2	None
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Possible Solution	
Possible Solutions:	Cor
Remove & Replace Entire Ramp.	N/A
Remove & Replace Gutter.	Yes
	Yes
	Yes
	N/A
	Yes
Surveyor Notes:	Yes
N/A	Yes
	No
	N/A
	N/A
PROW/ADA:	Yes
Not Found, R304.5.3, R305.2,	No
R302.7.2	N/A
	N/A
	N/A

Total Cost:	;	\$ 2600.00

Field Measurements/Component Compliance								
Comp	liance Description	Data	Comp	liance	Description	Data		
N/A	Ramp Length (in)	97.0	Yes	Ram	Slope (%)	5.5		
Yes	Ramp Width (in)	63.0	Yes	Yes Ramp XSlope (%)		2.4		
Yes	Flare Type L Curbed_NoWalk	Surface	N/A	Flare	Type RT	N/A		
Yes	Flare Slope LT (%)	N/A	N/A	Flare	Slope RT (%)	2.0		
N/A	Flare Traversable LT?	No	N/A	Flare	Traversable RT?	No		
Yes	Landing Length (in)	72.0	Yes	DWS	Provided?	Yes		
Yes	Landing Width (in)	70.0	Yes	DWS	Contrast?	Yes		
Yes	Landing Slope (%)	0.3	Yes	DWS	Length (in)	24.0		
No	Landing X Slope (%)	3.7	Yes	DWS	Full Width?	Yes		
N/A	Landing Curb? (Y/N)	No	No	DWS	Offset (in)	4.0		
N/A	Shared Landing?	No						
Yes	Gutter Ponding?	No	Yes	Gutte	er Slope (%)	0.9		
No	Gutter Lip Ht (in)	1.0	No	Gutte	er X Slope (%)	4.5		
N/A	Painted X Walk1?	No	N/A	Paint	ed X Walk2?	N/A		
	X Walk 1 Direction	To W		X Wa	lk 2 Direction	N/A		
N/A	X Walk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A		
	X Walk 1 Slope (%)	7.3		X Wa	lk 2 Slope (%)	N/A		
	X Walk 1 X Slope (%)	3.6		X Wa	lk 2 X Slope (%)	N/A		
N/A	Ramp inside XWalk1?	N/A	N/A	Ram	o inside XWalk2?	N/A		
	Road Slope (%)	N/A	N/A	Clear	Space?	Yes		
	Road X Slope (%)	N/A	N/A	Clear	Space to XWalk (in)	N/A		
Yes	Any Obstructions?	No	Yes	Storn	n Grate/Utility Hazard?	No		
	Obstruction Type			Storn	n Grate/Utility Type			
		N/A				N/A		
			Yes	Surfa	ce Condition? (G/P)	Good		
Sautanius al la	Physical Resident							





