


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 10022037		Main Street: BRYANT_FARMS_RD	Cross Street: N/A		Location: NW
ADA ID: 0CFF5C05C226		Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: Yes	Severity Score: 0
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		<b>Compliance</b>	<b>Description</b>	<b>Data</b>
	N/A		N/A	Ramp Length (in)	130.0
			Yes	Ramp Width (in)	67.0
			Yes	Ramp Slope (%)	4.1
			Yes	Ramp XSlope (%)	1.5
			Yes	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	No
	Surveyor Notes:		Yes	Landing Length (in)	99.0
	N/A		Yes	Landing Width (in)	67.0
			Yes	Landing Slope (%)	0.8
			Yes	Landing X Slope (%)	0.3
			N/A	Landing Curb? (Y/N)	No
			N/A	Shared Landing?	No
			Yes	Gutter Ponding?	No
			Yes	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To NE
				X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	2.4
				X Walk 1 X Slope (%)	1.2
			N/A	Ramp inside XWalk1?	N/A
			Yes	Any Obstructions?	No
				Obstruction Type	
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	8.2
PROW/ADA:					
N/A					
Street 1 Name	ENTRANCE				
Stop Condition-Street 1	StopSign				
Street 2 Name	N/A				
Stop Condition-Street 2	N/A				
Total Cost:		\$ 0.00			

