

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10379	Main Street: ANDERSON_ST	Cross Street: E_SUGAR_CREEK_RD	Location:	N
ADA ID: 0D982BA8C0A8	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score: 5.25
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance		



Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.3, R304.2.2-Perp, R304.3.2-Para, R304.2.3, R305.2

Total Cost: \$ 1850.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	61.5	Yes	Ramp Slope (%)	8.1
Yes	Ramp Width (in)	50.0	No	Ramp XSlope (%)	4.5
N/A	Flare Type LT	Sloped	No	Flare Type RT	N/A
N/A	Flare Slope LT (%)	2.1	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	No
Yes	Landing Length (in)	64.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	50.5	Yes	DWS Contrast?	Yes
No	Landing Slope (%)	3.6	Yes	DWS Length (in)	24.0
No	Landing X Slope (%)	6.5	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	9.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	0.6
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.1
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To SW		X Walk 2 Direction	N/A
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	2.8		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	0.1		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear Space?	Yes
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good

Street 1 Name **E SUGAR CREEK RD**

Stop Condition-Street 2 **None**

Street 2 Name **N/A**

Stop Condition-Street 1 **N/A**

