

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

85.0

66.0

9.5

3.8

4.1

2.3

N/A

N/A N/A

N/A

N/A

Intersection ID: 18844 Main Street: NATIONS_FORD_RD Cross Street: TYVOLA_RD Location: NE

ADA ID: 0FF63ECE650E Ramp Type: Combination1 Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 13.75

Compliance Description

Ramp Length LT (in)

Ramp Width LT (in)

Ramp Slope LT (%)

Ramp Length (in)

Ramp Width (in)

Flare Slope LT (%)

Landing Length (in)

Landing Width (in)

Landing Slope (%)

Landing X Slope (%)

Landing Curb? (Y/N)

Shared Landing?

Gutter Ponding?

Gutter Lip Ht (in)

Painted X Walk1?

X Walk 1 Direction

X Walk 1 Width (in)

X Walk 1 Slope (%)

X Walk 1 X Slope (%)

Ramp inside XWalk1?

Road Slope (%)

Flare Traversable LT?

Flare Type LT

Ramp XSlope LT (%)

N/A

Yes

Yes

Yes

N/A

Yes

N/A

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

N/A

Yes

No

No

Yes

No

N/A

Compliance Description

Ramp Length RT (in)

Ramp Width RT (in)

Ramp Slope RT (%)

Ramp XSlope RT (%)

Ramp Slope (%)

Flare Type RT

Ramp XSlope (%)

Flare Slope RT (%)

DWS Provided?

DWS Contrast?

DWS Length (in)

DWS Full Width?

DWS Offset (in)

Gutter Slope (%)

Gutter X Slope (%)

Painted X Walk2?

X Walk 2 Direction

X Walk 2 Width (in)

X Walk 2 Slope (%)

X Walk 2 X Slope (%)

Ramp inside XWalk2?

Flare Traversable RT?

Data

62.0

71.0

3.0

1.1

67.0

48.0

N/A

No

To W

N/A

0.3

3.9

N/A



Street 1 Name

YieldSign
Stop Condition-Street 1

Street 2 Name

N/A
Stop Condition-Street 2

N/A

Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

LT RP < 5%

PROW/ADA:

Not Found, R304.5.3, R304.3.2





Total Cost:



1800.00

N/A		Clear Space?	N/A
N/A	N/A	Clear Space to XWalk (in)	N/A
	N/A	Any Obstruction?	N/A
		Obstruction Type	
			N/A
	N/A	Storm Grate/Utility Hazard?	N/A
		Storm Grate/Utility Type	
			N/A
	Yes	Surface Condition? (G/P)	Good
		Curb Slope (%)	13.0