


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 19938	Main Street: ARCHDALE_DR	Cross Street: MONTCREST_DR	Location: NW
ADA ID: 10EF1F2E9ED9	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
Severity Score: 12.5			
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	

	Possible Solutions:		Compliance		Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	70.0	Yes	Ramp Slope (%)	7.1	
			Yes	Ramp Width (in)	59.0	No	Ramp XSlope (%)	5.8	
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
			N/A	Shared Landing?	N/A				
Surveyor Notes:		N/A	N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
				N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
				N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
					X Walk 1 Direction	To S		X Walk 2 Direction	N/A
				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
					X Walk 1 Slope (%)	1.2		X Walk 2 Slope (%)	N/A
					X Walk 1 X Slope (%)	4.2		X Walk 2 X Slope (%)	N/A
				N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
					Road Slope (%)	N/A	N/A	Clear Space?	N/A
					Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
					Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A
						Yes		Surface Condition? (G/P)	Good
Street 1 Name		ARCHDALE DR							
Stop Condition-Street 2		None							
Street 2 Name		N/A							
Stop Condition-Street 1		N/A							
Total Cost:		\$ 1850.00							

