


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 3648	Main Street: ARMITAGE_DR	Cross Street: WHITE_CASCADE_DR	Location: SW
ADA ID: 10F718D5E022	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No
			Severity Score: 2.5

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
 Street 1 Name WHITE CASCADE DR Stop Condition-Street 1 StopSign Street 2 Name N/A Stop Condition-Street 2 N/A	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	51.0	No	Grade Break?	No
	Remove & Replace Gutter.		Yes	Ramp Width (in)	49.5	N/A	Grade Break Slope (%)	7.6
			Yes	Ramp Slope (%)	7.6	N/A	Grade Break XSlope (%)	0.2
			Yes	Ramp XSlope (%)	1.5			
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			Yes	Landing Length (in)	53.0	Yes	DWS Provided?	Yes
			Yes	Landing Width (in)	48.0	Yes	DWS Contrast?	Yes
Surveyor Notes:		N/A	No	Landing Slope (%)	2.3	Yes	DWS Length (in)	24.5
PROW/ADA: R304.2.2-Perp, R304.3.2-Para, R304.5.2, R305.1.4, R305.2, R304.5.3		Yes	Landing X Slope (%)	1.4	No	DWS Full Width?	No	
		N/A	Landing Curb? (Y/N)	N/A	No	DWS Offset LT (in)	3.0	
		N/A	Shared Landing?	No	Yes	DWS Offset RT (in)	47.0	
		Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	1.6	
		Yes	Gutter Lip Ht (in)	0.0	No	Gutter X Slope (%)	5.6	
		N/A	Painted X Walk1?	No		Road Slope (%)	0.9	
			X Walk 1 Direction	To NE		Road X Slope (%)	7.1	
			X Walk 1 Width (in)	N/A		Clear Space?	Yes	
			X Walk 1 Slope (%)	0.9	N/A	Clear Space to XWalk (in)	N/A	
			X Walk 1 X Slope (%)	7.1	Yes	Storm Grate/Utility Hazard?	No	
		N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type		
		Yes	Any Obstructions?	No			N/A	
			Obstruction Type		Yes	Surface Condition? (G/P)	Good	
					N/A	Curb Slope (%)	8.3	
Total Cost: \$ 2350.00								

