


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 3285	Main Street: MALLARD_CREEK_RD	Cross Street: JOHNSTON_OEHLER_RD	Location:	S
ADA ID: 13AC34AB948F	Ramp Type: Combination1	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 22.5

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance							
	Possible Solutions:		Remove & Replace Entire Ramp.		Compliance	Description	Data	Compliance	Description	Data
					N/A	Ramp Length LT (in)	55.0	N/A	Ramp Length RT (in)	51.0
					Yes	Ramp Width LT (in)	48.0	No	Ramp Width RT (in)	47.0
					Yes	Ramp Slope LT (%)	5.3	No	Ramp Slope RT (%)	8.7
					Yes	Ramp XSlope LT (%)	1.1	No	Ramp XSlope RT (%)	2.1
					N/A	Ramp Length (in)	24.0	Yes	Ramp Slope (%)	6.7
					Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	0.2
	Surveyor Notes:				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
	N/A				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
					N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
				N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
				N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
				N/A	Shared Landing?	N/A				
				N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
				N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
				N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A	
					X Walk 1 Direction	To NE		X Walk 2 Direction	N/A	
					X Walk 1 Width (in)	104.0		X Walk 2 Width (in)	N/A	
					X Walk 1 Slope (%)	0.5		X Walk 2 Slope (%)	N/A	
					X Walk 1 X Slope (%)	3.1		X Walk 2 X Slope (%)	N/A	
				N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A	
					Road Slope (%)	N/A		Clear Space?	N/A	
					Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
							N/A	Any Obstruction?	N/A	
								Obstruction Type	N/A	
							N/A	Storm Grate/Utility Hazard?	N/A	
								Storm Grate/Utility Type	N/A	
				Yes	Surface Condition? (G/P)				Good	
					Curb Slope (%)				N/A	

Street 1 Name

Signal

Stop Condition-Street 1

JOHNSTON OEHLER RD

Street 2 Name

N/A




Stop Condition-Street 2

N/A

Total Cost:

\$

1800.00



Street 1 Name	Signal
Stop Condition-Street 1	JOHNSTON OEHLER RD
Street 2 Name	N/A
Stop Condition-Street 2	N/A

Total Cost: \$ 1800.00

