

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 21622 Main Street: OLD BELL RD Cross Street: SARDIS_RD Location: NW **Overall Compliance: No** ADA ID: 13AFC50D9EA3 Ramp Type: Perp Initial Pass/Fail: Fail Severity Score: 21.25

Codes/Mitigation Info/Possible Solution



Street 1 Name **SARDIS RD** Stop Condition-Street 2 None Street 2 Name N/A Stop Condition-Street 1 N/A

Possible Solution					
Possible Solutions:					
Remove & Replace Entire Ramp.					
	ı				
	I				
	I				
	I				
	ı				
Surveyor Notes:	ı				
N/A	ı				
	ı				
PROW/ADA:					
Not Found, R304.5.1, R304.2.2					

Total Cost:



1850.00

Field Measurements/Component Compliance								
Compl	iance Description	Data	Compl	iance	Description	Data		
N/A	Ramp Length (in)	60.0	No	Ramp	Slope (%)	9.6		
No	Ramp Width (in)	44.0	Yes	Ramp	XSlope (%)	0.9		
N/A	Flare Type LT	N/A	N/A	Flare	Type RT	N/A		
N/A	Flare Slope LT (%)	N/A	N/A	Flare	Slope RT (%)	N/A		
N/A	Flare Traversable LT?	N/A	N/A	Flare	Traversable RT?	N/A		
N/A	Landing Length (in)	N/A	N/A	DWS	Provided?	N/A		
N/A	Landing Width (in)	N/A	N/A	DWS	Contrast?	N/A		
N/A	Landing Slope (%)	N/A	N/A	DWS	Length (in)	N/A		
N/A	Landing X Slope (%)	N/A	N/A	DWS	Full Width?	N/A		
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS	Offset (in)	N/A		
N/A	Shared Landing?	N/A						
N/A	Gutter Ponding?	N/A	N/A	Gutte	r Slope (%)	N/A		
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutte	r X Slope (%)	N/A		
N/A	Painted X Walk1?	No	N/A	Paint	ed X Walk2?	N/A		
	X Walk 1 Direction	To SW		X Wa	lk 2 Direction	N/A		
N/A	X Walk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A		
	X Walk 1 Slope (%)	0.1		X Wa	lk 2 Slope (%)	N/A		
	X Walk 1 X Slope (%)	0.8		X Wa	lk 2 X Slope (%)	N/A		
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp	inside XWalk2?	N/A		
	Road Slope (%)	N/A	N/A	Clear	Space?	N/A		
	Road X Slope (%)	N/A	N/A	Clear	Space to XWalk (in)	N/A		
N/A	Any Obstructions?	N/A	N/A	Storm	n Grate/Utility Hazard?	N/A		
	Obstruction Type			Storm	n Grate/Utility Type			
		N/A				N/A		
			Yes	Surfa	ce Condition? (G/P)	Good		

