


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 16560	Main Street: OLD_PINEVILLE_RD	Cross Street: E_PETERSON_DR	Location: NW
ADA ID: 15CB2F73A1A8	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 25	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance											
	Possible Solutions:		<b>Compliance</b>			<b>Description</b>			<b>Data</b>					
	<b>Remove &amp; Replace Entire Ramp.</b>		<b>N/A</b>	Ramp Length (in)		<b>185.0</b>		<b>Yes</b>	Ramp Slope (%)		<b>9.1</b>			
			<b>Yes</b>	Ramp Width (in)		<b>72.0</b>		<b>No</b>	Ramp XSlope (%)		<b>5.4</b>			
			<b>N/A</b>	Flare Type LT		<b>N/A</b>		<b>N/A</b>	Flare Type RT		<b>N/A</b>			
			<b>N/A</b>	Flare Slope LT (%)		<b>N/A</b>		<b>N/A</b>	Flare Slope RT (%)		<b>N/A</b>			
			<b>N/A</b>	Flare Traversable LT?		<b>N/A</b>		<b>N/A</b>	Flare Traversable RT?		<b>N/A</b>			
			<b>N/A</b>	Landing Length (in)		<b>N/A</b>		<b>N/A</b>	DWS Provided?		<b>N/A</b>			
			<b>N/A</b>	Landing Width (in)		<b>N/A</b>		<b>N/A</b>	DWS Contrast?		<b>N/A</b>			
			<b>N/A</b>	Landing Slope (%)		<b>N/A</b>		<b>N/A</b>	DWS Length (in)		<b>N/A</b>			
			<b>N/A</b>	Landing X Slope (%)		<b>N/A</b>		<b>N/A</b>	DWS Full Width?		<b>N/A</b>			
Surveyor Notes:		<b>N/A</b>			<b>N/A</b>	Landing Curb? (Y/N)		<b>N/A</b>		<b>N/A</b>	DWS Offset (in)		<b>N/A</b>	
PROW/ADA:		<b>R304.5.3</b>			<b>N/A</b>	Shared Landing?		<b>N/A</b>						
					<b>N/A</b>	Gutter Ponding?		<b>N/A</b>		<b>N/A</b>	Gutter Slope (%)		<b>N/A</b>	
					<b>N/A</b>	Gutter Lip Ht (in)		<b>N/A</b>		<b>N/A</b>	Gutter X Slope (%)		<b>N/A</b>	
					<b>N/A</b>	Painted X Walk1?		<b>Yes</b>		<b>N/A</b>	Painted X Walk2?		<b>N/A</b>	
						X Walk 1 Direction		<b>To SW</b>			X Walk 2 Direction		<b>N/A</b>	
					<b>N/A</b>	X Walk 1 Width (in)		<b>120.0</b>		<b>N/A</b>	X Walk 2 Width (in)		<b>N/A</b>	
						X Walk 1 Slope (%)		<b>2.3</b>			X Walk 2 Slope (%)		<b>N/A</b>	
						X Walk 1 X Slope (%)		<b>4.6</b>			X Walk 2 X Slope (%)		<b>N/A</b>	
					<b>N/A</b>	Ramp inside XWalk1?		<b>Yes</b>		<b>N/A</b>	Ramp inside XWalk2?		<b>N/A</b>	
						Road Slope (%)		<b>N/A</b>		<b>N/A</b>	Clear Space?		<b>N/A</b>	
						Road X Slope (%)		<b>N/A</b>		<b>N/A</b>	Clear Space to XWalk (in)		<b>N/A</b>	
					<b>N/A</b>	Any Obstructions?		<b>N/A</b>		<b>N/A</b>	Storm Grate/Utility Hazard?		<b>N/A</b>	
						Obstruction Type					Storm Grate/Utility Type			
								<b>N/A</b>					<b>N/A</b>	
										<b>Yes</b>	Surface Condition? (G/P)		<b>Good</b>	
Total Cost:				<b>\$</b>	<b>1850.00</b>									

