


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 15205		Main Street: CHEROKEE_RD		Cross Street: FENTON_PL		Location: NE					
ADA ID: 160600DAFE9E		Ramp Type: Directional1		Initial Pass/Fail: Fail		Overall Compliance: No		Severity Score: 12.5			
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance							
				Possible Solutions:		Compliance		Description		Data	
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		63.5	
Surveyor Notes:				N/A		Yes		Ramp Width (in)		57.0	
						No		Ramp Slope (%)		11.8	
PROW/ADA:				R304.2.2		Yes		Ramp XSlope (%)		0.5	
						N/A		Flare Type LT		N/A	
						N/A		Flare Slope LT (%)		N/A	
						N/A		Flare Traversable LT?		N/A	
						N/A		Landing Length (in)		0.0	
						N/A		Landing Width (in)		0.0	
						N/A		Landing Slope (%)		0.0	
						N/A		Landing X Slope (%)		0.0	
						N/A		Landing Curb? (Y/N)		N/A	
						N/A		Shared Landing?		N/A	
						N/A		Gutter Ponding?		0.0	
						N/A		Gutter Lip Ht (in)		0.0	
						N/A		Painted X Walk1?		No	
								X Walk 1 Direction		To SE	
								X Walk 1 Width (in)		N/A	
								X Walk 1 Slope (%)		1.0	
								X Walk 1 X Slope (%)		0.9	
						N/A		Ramp inside XWalk1?		N/A	
						N/A		Any Obstructions?		N/A	
								Obstruction Type		Yes	
								Surface Condition? (G/P)		Good	
								Curb Slope (%)		N/A	
										16.2	

