


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 15402	Main Street: MARSH_RD	Cross Street: NEW_BERN_ST	Location: NW
ADA ID: 1750838D6507	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	25.0	No	Ramp Slope (%)	8.6
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	2.8
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Surveyor Notes:			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
PROW/ADA:			Not Found, R304.2.2, R304.5.3	Shared Landing?	N/A			
				Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
				Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
				Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To NE		X Walk 2 Direction	N/A
				X Walk 1 Width (in)	110.0	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	0.5		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	0.8		X Walk 2 X Slope (%)	N/A
				Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	N/A	N/A	Clear Space?	N/A
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
				Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
				Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good
Total Cost:			\$ 1850.00					
Street 1 Name			NEW BERN ST					
Stop Condition-Street 2			Signal					
Street 2 Name			N/A					
Stop Condition-Street 1			N/A					

