

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Data

37.0

46.0

11.2

4.0

1.4

3.7

N/A

N/A

N/A

N/A

Good

10.4

Main Street: ARBORHILL RD Intersection ID: 26586 Cross Street: WINTHORP RIDGE RD Location: Ε Initial Pass/Fail: Fail **Overall Compliance: No** 22.5 **ADA ID: 1967AC46ABA9** Ramp Type: Combination1 **Severity Score:** 

**Codes/Mitigation Info/Possible Solution** 

Field Measurements/Component Compliance

N/A

No

No

Yes

No

N/A

N/A

N/A

N/A

Compliance Description

Ramp Length RT (in)

Ramp Width RT (in)

Ramp Slope RT (%)

Ramp Slope (%)

Flare Type RT

Ramp XSlope (%)

Flare Slope RT (%)

DWS Provided?

Flare Traversable RT?

Surface Condition? (G/P)

Curb Slope (%)

Ramp XSlope RT (%)

Data

37.0

46.0

3.0 No

4.7

50.0

42.5

N/A

N/A

N/A

N/A

Ramp Length LT (in)

Ramp Width LT (in)

Ramp Slope LT (%)

Ramp Length (in)

Ramp Width (in)

Flare Slope LT (%)

Landing Length (in)

Flare Traversable LT?

Flare Type LT

Ramp XSlope LT (%)



StopSign Street 1 Name Stop Condition-Street 1 WINTHORP RIDGE RD Street 2 Name N/A Stop Condition-Street 2 N/A Possible Solutions: Compliance Description Remove & Replace Entire Ramp. N/A No Yes No N/A No Surveyor Notes: N/A LT RP < 5% N/A N/A N/A N/A PROW/ADA: N/A Not Found, R304.5.1, R304.5.1, N/A R304.5.3, R304.3.2 N/A N/A N/A N/A N/A





Total Cost:



1800.00

N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To SW		X Walk 2 Direction	N/A
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	5.2		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	3.0		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A		Clear Space?	N/A
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			N/A	Any Obstruction?	N/A
				Obstruction Type	
					N/A
			N/A	Storm Grate/Utility Hazard?	N/A
				Storm Grate/Utility Type	
					N/A

Yes