

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10035443	Main Street: RANDOLPH_RD	Cross Street: N/A	Location: S
ADA ID: 1A4D5FADBE44	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 21.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		No	Ramp Length (in)	70.0
			No	Ramp Width (in)	37.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			No	Painted X Walk1?	No
				X Walk 1 Direction	To NE
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	12.0
				X Walk 1 X Slope (%)	10.9
			N/A	Ramp inside XWalk1?	N/A
Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1, R304.2.2			N/A	Ramp inside XWalk2?	N/A
			5.3	Clear Space?	N/A
			13.0	Clear Space to XWalk (in)	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
				Storm Grate/Utility Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good
Total Cost:		\$ 3200.00			

