


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 9242	Main Street: COVECREEK_DR	Cross Street: TOANO_RD	Location: SW
ADA ID: 1B577845B076	Ramp Type: Para	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length LT (in)	22.0
			Yes	Ramp Width LT (in)	48.0
			No	Ramp Slope LT (%)	9.8
			Yes	Ramp XSlope LT (%)	1.7
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
			N/A	Landing Curb? (Y/N)	N/A
<p>Surveyor Notes:</p> <p>RT RP < 5%, NO RT SW</p> <p>PROW/ADA:</p> <p>R304.3.2, R304.5.3</p>			N/A	Ramp Slope RT (%)	2.1
			No	Ramp XSlope RT (%)	3.7
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Gutter Slope (%)	N/A
			N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	No
			N/A	Painted X Walk2?	N/A
			N/A	X Walk 1 Direction	To NE
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	2.0
				X Walk 1 X Slope (%)	0.7
			N/A	Ramp inside XWalk1?	N/A
			N/A	Ramp inside XWalk2?	N/A
			N/A	Road Slope (%)	N/A
			N/A	Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good
Total Cost:				Curb Slope (%)	15.0
			\$	1600.00	

