


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 9604		Main Street: FREEDOM_DR		Cross Street: S_I-85_RA		Location:		E			
ADA ID: 1C44BAB2E87E		Ramp Type: Directional1		Initial Pass/Fail: Fail		Overall Compliance: No		Severity Score: 1.25			
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance							
				Possible Solutions:		Compliance		Description		Data	
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		53.0	
Surveyor Notes:				N/A		Yes		Ramp Width (in)		60.0	
						Yes		Ramp Slope (%)		2.3	
PROW/ADA:				R304.5.3		No		Ramp XSlope (%)		2.6	
						N/A		Flare Type LT		N/A	
				N/A		Flare Slope LT (%)		N/A		N/A	
				N/A		Flare Traversable LT?		N/A		N/A	
				N/A		Landing Length (in)		0.0		N/A	
				N/A		Landing Width (in)		0.0		N/A	
				N/A		Landing Slope (%)		0.0		N/A	
				N/A		Landing X Slope (%)		0.0		N/A	
				N/A		Landing Curb? (Y/N)		N/A		N/A	
				N/A		Shared Landing?		N/A		N/A	
				N/A		Gutter Ponding?		0.0		N/A	
				N/A		Gutter Lip Ht (in)		0.0		N/A	
				N/A		Painted X Walk1?		No		Road Slope (%)	
						X Walk 1 Direction		To N		Road X Slope (%)	
						X Walk 1 Width (in)		N/A		Clear Space?	
						X Walk 1 Slope (%)		2.7		N/A	
						X Walk 1 X Slope (%)		3.2		N/A	
				N/A		Ramp inside XWalk1?		N/A		Storm Grate/Utility Hazard?	
				N/A		Any Obstructions?		N/A		Storm Grate/Utility Type	
						Obstruction Type		Yes		Surface Condition? (G/P)	
						N/A		N/A		Curb Slope (%)	
Total Cost:				\$		1600.00					
Street 1 Name				S I-85 RA							
Stop Condition-Street 1				YieldSign							
Street 2 Name				N/A							
Stop Condition-Street 2				N/A							

