


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 23662	Main Street: CARMEL_RD	Cross Street: RED_OAK_LN	Location: SW
ADA ID: 1D5D58B42504	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No Severity Score: 33.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		No	Ramp Length (in)	59.0
			No	Ramp Width (in)	47.5
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.5.1, R304.2.2, R304.5.3</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
<p>Total Cost:</p> <p>\$ 3200.00</p>			No	Painted X Walk1?	No
			To N	X Walk 2 Direction	To E
			N/A	X Walk 2 Width (in)	N/A
			7.7	X Walk 2 Slope (%)	2.8
			0.5	X Walk 2 X Slope (%)	4.4
			N/A	Ramp inside XWalk2?	N/A
			2.0	Clear Space?	N/A
			5.2	Clear Space to XWalk (in)	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
			N/A	Storm Grate/Utility Type	N/A
<p>Obstruction Type</p>			N/A	Surface Condition? (G/P)	Good

