


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 9925	Main Street: TENNYSON_DR	Cross Street: TUCKASEEGEE_RD	Location: W
ADA ID: 215048450DB9	Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		<b>Compliance</b>	<b>Description</b>	<b>Data</b>	
	<b>Remove &amp; Replace Entire Ramp.</b>		N/A	Ramp Length (in)	96.0	N/A
			Yes	Ramp Width (in)	49.0	N/A
			No	Ramp Slope (%)	11.0	N/A
			No	Ramp XSlope (%)	3.7	N/A
			N/A	Flare Type LT	N/A	N/A
			N/A	Flare Slope LT (%)	N/A	N/A
			N/A	Flare Traversable LT?	N/A	N/A
			N/A	Flare Traversable RT?	N/A	N/A
			N/A	Landing Length (in)	0.0	N/A
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>R304.2.2, R304.5.3</p>			N/A	Landing Width (in)	0.0	N/A
			N/A	Landing Slope (%)	0.0	N/A
			N/A	Landing X Slope (%)	0.0	N/A
			N/A	Landing Curb? (Y/N)	N/A	N/A
			N/A	Shared Landing?	N/A	N/A
			N/A	Gutter Ponding?	Yes	N/A
			N/A	Gutter Lip Ht (in)	1.0	N/A
			N/A	Painted X Walk1?	No	N/A
				X Walk 1 Direction	To E	N/A
				X Walk 1 Width (in)	N/A	N/A
<p>Street 1 Name</p> <p>Stop Condition-Street 1</p> <p>Street 2 Name</p> <p>Stop Condition-Street 2</p>				X Walk 1 Slope (%)	0.2	N/A
				X Walk 1 X Slope (%)	1.1	N/A
			N/A	Ramp inside XWalk1?	N/A	N/A
			N/A	Any Obstructions?	N/A	N/A
				Obstruction Type		N/A
					Yes	N/A
					N/A	N/A
					Yes	N/A
					N/A	N/A
					Yes	N/A
Total Cost:		\$ 1600.00				

