


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 14546	Main Street: GREENWOOD_CLIFF	Cross Street: HARDING_PL	Location: E
ADA ID: 215CE720EA69	Ramp Type: BlendTrans1	Initial Pass/Fail: Pass	Overall Compliance: No
Severity Score: 0.25			
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Remove & Replace Gutter.

Surveyor Notes:

LNDG SLOPE NEGATIVE

PROW/ADA:

Not Found, R304.5.3, R304.2.1, R304.2.2-Perp, R304.3.2-Para

Total Cost: \$ 3950.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	37.0	Yes	BlendTrans Slope (%)	0.7
Yes	Ramp Width (in)	48.0	No	BlendTrans XSlope (%)	3.9
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	Sloped
N/A	Flare Slope LT (%)	0.5	N/A	Flare Slope RT (%)	3.4
N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
Yes	Landing Length (in)	49.0	Yes	DWS Provided?	Yes
No	Landing Width (in)	33.0	Yes	DWS Contrast?	Yes
No	Landing Slope (%)	4.6	Yes	DWS Length (in)	24.0
Yes	Landing X Slope (%)	1.5	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset (in)	0.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	2.8
Yes	Gutter Lip Ht (in)	0.0	No	Gutter X Slope (%)	3.9
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To NW		X Walk 2 Direction	To SW
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	8.0		X Walk 2 Slope (%)	2.9
	X Walk 1 X Slope (%)	6.1		X Walk 2 X Slope (%)	6.8
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	3.1		Clear Space?	No
	Road X Slope (%)	7.0	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			No	Curb Slope (%)	17.3

Street 1 Name **GREENWOOD CLIFF**

Stop Condition-Street 1 **StopSign**

Street 2 Name **HARDING PL**

Stop Condition-Street 2 **None**

