

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 11628Main Street: W_8TH_STCross Street: N_PINE_STLocation:SADA ID: 2492B70A8E16Ramp Type: PerpInitial Pass/Fail: FailOverall Compliance: NoSeverity Score: 12.5

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name W 8TH ST
Stop Condition-Street 2 None
Street 2 Name N/A
Stop Condition-Street 1 N/A

Total Cost: \$ 1850.00

Compl	iance Description	Data	Comp	liance Description	Data
N/A	Ramp Length (in)	55.0	Yes	Ramp Slope (%)	7.0
Yes	Ramp Width (in)	83.0	No	Ramp XSlope (%)	6.0
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To NE		X Walk 2 Direction	N/A
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	3.7		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	0.9		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear Space?	N/A
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk	(in) N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Ha	zard? N/A
	Obstruction Type			Storm Grate/Utility Typ	oe .
		N/A			N/A
			Yes	Surface Condition? (G	(P) Good





