

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

19.0

72.0

10.0

1.0

7.8

6.9

N/A

No

N/A

5.5

2.8

N/A

N/A

N/A

N/A

N/A

N/A

N/A

Good 15.8

To NE

Intersection ID: 20051 Main Street: ARCHDALE_DR Cross Street: BURNLEY_RD Location: W

ADA ID: 26A9B3FAC542 Ramp Type: Combination1Diag Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name
Stop Condition-Street 1
Street 2 Name
Stop Condition-Street 2

StopSign BURNLEY RD None ARCHDALE DR Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.1, R304.5.3, R304.3.2

Total Cost: \$ 3200.00

Compliance Description Data Compliance Description N/A N/A Ramp Length LT (in) 35.0 Ramp Length RT (in) Yes Ramp Width LT (in) 71.0 Yes Ramp Width RT (in) No 10.2 No Ramp Slope LT (%) Ramp Slope RT (%) Ramp XSlope LT (%) Yes Ramp XSlope RT (%) Yes 0.8 N/A Ramp Length (in) 71.0 Yes Ramp Slope (%) 45.0 No Ramp XSlope (%) No Ramp Width (in) N/A Flare Type LT N/A N/A Flare Type RT N/A N/A Flare Slope LT (%) N/A Flare Slope RT (%) N/A Flare Traversable LT? N/A N/A Flare Traversable RT? N/A Landing Length (in) N/A N/A DWS Provided? N/A N/A **DWS Contrast?** N/A Landing Width (in) N/A Landing Slope (%) N/A N/A DWS Length (in) N/A Landing X Slope (%) N/A N/A DWS Full Width? N/A Landing Curb? (Y/N) N/A N/A DWS Offset (in) N/A Shared Landing? N/A N/A Gutter Ponding? N/A N/A Gutter Slope (%) N/A N/A Gutter Lip Ht (in) N/A Gutter X Slope (%) N/A N/A Painted X Walk1? No Painted X Walk2? To SE X Walk 1 Direction X Walk 2 Direction X Walk 1 Width (in) N/A X Walk 2 Width (in) 3.2 X Walk 1 Slope (%) X Walk 2 Slope (%) X Walk 1 X Slope (%) 4.9 X Walk 2 X Slope (%)

N/A

4.1

0.8

N/A

N/A

N/A

N/A

Yes

Ramp inside XWalk2?

Clear Space to XWalk (in)

Storm Grate/Utility Hazard?

Storm Grate/Utility Type

Surface Condition? (G/P)

Clear Space?

Any Obstruction?

Obstruction Type

Curb Slope (%)







N/A

Ramp inside XWalk1?

Road Slope (%)