


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 14120	Main Street: HAWKINS_ST	Cross Street: DOGGETT_ST	Location: SW
ADA ID: 26BD0A81962B	Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		<b>Compliance</b>	<b>Description</b>	<b>Data</b>	
	<b>Remove &amp; Replace Entire Ramp.</b>		N/A	Ramp Length (in)	55.0	
			Yes	Ramp Width (in)	99.0	
			No	Ramp Slope (%)	9.4	
			No	Ramp XSlope (%)	4.4	
			N/A	Flare Type LT	N/A	
			N/A	Flare Slope LT (%)	N/A	
			N/A	Flare Traversable LT?	N/A	
			N/A	Landing Length (in)	0.0	
			N/A	Landing Width (in)	0.0	
			N/A	Landing Slope (%)	0.0	
			N/A	Landing X Slope (%)	0.0	
			N/A	Landing Curb? (Y/N)	N/A	
			N/A	Shared Landing?	N/A	
			N/A	Gutter Ponding?	0.0	
			N/A	Gutter Lip Ht (in)	0.0	
			N/A	Painted X Walk1?	No	
				X Walk 1 Direction	To NE	
				X Walk 1 Width (in)	N/A	
				X Walk 1 Slope (%)	4.2	
				X Walk 1 X Slope (%)	6.7	
<p>Surveyor Notes:</p> <p>N/A</p>			N/A	Ramp inside XWalk1?	N/A	
			N/A	Any Obstructions?	N/A	
<p>PROW/ADA:</p> <p>R304.2.2, R304.5.3</p>				Obstruction Type		
Total Cost:			\$	1600.00		
					Yes	Surface Condition? (G/P)
					N/A	Curb Slope (%)
						Good
						4.2

