


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10035052		Main Street: PROVIDENCE_RD		Cross Street: N/A		Location: NE					
ADA ID: 26C90AD95B3F		Ramp Type: Directional1		Initial Pass/Fail: Fail		Overall Compliance: No		Severity Score: 25			
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance							
				Possible Solutions:		Compliance		Description		Data	
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		48.0	
Surveyor Notes:				N/A		Yes		Ramp Width (in)		48.0	
						Yes		Ramp Slope (%)		3.4	
PROW/ADA:				R304.5.3		No		Ramp XSlope (%)		9.3	
						N/A		Flare Type LT		N/A	
				N/A		Flare Slope LT (%)		N/A		N/A	
				N/A		Flare Traversable LT?		N/A		N/A	
				N/A		Landing Length (in)		0.0		N/A	
				N/A		Landing Width (in)		0.0		N/A	
				N/A		Landing Slope (%)		0.0		N/A	
				N/A		Landing X Slope (%)		0.0		N/A	
				N/A		Landing Curb? (Y/N)		N/A		N/A	
				N/A		Shared Landing?		N/A		N/A	
				N/A		Gutter Ponding?		0.0		N/A	
				N/A		Gutter Lip Ht (in)		0.0		N/A	
				N/A		Painted X Walk1?		No		Road Slope (%)	
						X Walk 1 Direction		To S		Road X Slope (%)	
Street 1 Name				ENTRANCE				X Walk 1 Width (in)		N/A	
				None				X Walk 1 Slope (%)		0.5	
Street 2 Name				N/A				X Walk 1 X Slope (%)		0.8	
				N/A		N/A		Ramp inside XWalk1?		N/A	
Stop Condition-Street 1						N/A		Any Obstructions?		N/A	
						Obstruction Type		Yes		Surface Condition? (G/P)	
Stop Condition-Street 2						N/A		N/A		Curb Slope (%)	
Total Cost:				\$		1600.00					

